



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

April 2, 2020
File: SR 2783248

VIA EMAIL

GURKEERAT SINGH HIRA
BVD HOLDINGS COCHRANE INC
130 DELTA PARK BLVD
BRAMPTON ON L6T 5E7
gurkeerat.hira@bvdpetroleum.com

Dear GURKEERAT SINGH HIRA,

Re: Application for a Variance from Clause 2.4.2.1 of the Liquid Fuels Handling Code, Technical Standards & Safety Act R.S.O. 2000 for 54 Hwy 11 North, Cochrane

You have requested permission to leave an out-of-service underground gasoline storage tank in place. (The tank has a hole in its secondary containment wall.) You have indicated that removal of the tank will compromise the stability of the adjacent underground tanks.

A & A Environmental Consultants Inc. completed an environmental assessment which supports the variance application to keep the tank in the ground.

As part of the assessment, four boreholes were drilled in the areas as close to the tank as possible, based on the available area and utility line clearances. Three of the boreholes were completed as monitoring wells. Selected soil samples from each borehole and groundwater samples from three monitoring wells were submitted to an accredited laboratory for analysis of volatile organic compounds (VOCs), petroleum hydrocarbon fractions 1 to 4 (PHC F1 to F4) and metals. The soil and groundwater samples met the applicable site condition standards.

Your variance application dated February 19, 2020, has been approved.

Please be advised that this variance will not take effect until 15 days from the date of posting the decision on the environmental registry. This decision of the Director is subject to a right of appeal, under the Environmental Bill of Rights, if such an appeal is filed within 15 days from date of posting. In the event an appeal is filed, this decision of the director may be subsequently stayed, disallowed or significantly altered. Notice of an appeal will be placed on the Environmental Bill of Rights registry.

This variance is allowed under the authority of subsection 36.(3)(c) of the *Technical Standards and Safety Act, 2000*, (the "Act") and subject to such conditions as may be specified herein, being that:

- The applicant shall ensure that the fill and vent pipes associated with the subject tank have been removed;
- The applicant shall empty the tank of all product and material and clean and purge the tank and ensure that the tank is completely filled with concrete;
- Non-conformity with the conditions specified shall thereby cause the allowed variance to become null and void;
- The applicant accepts full responsibility for any and all damages resulting from the use of the thing to which the variance applies. The applicant further accepts full responsibility for any impacts to the health and safety of any person in consequence of the allowance of the variance

or of non-conformity with the conditions specified. The Technical Standards and Safety Authority accepts no responsibility for any such damages or impacts;

- In the event of any claims against the Technical Standards and Safety Authority arising from allowance of the variance or non-conformity with the conditions specified, the applicant agrees to indemnify the Technical Standards and Safety Authority and agrees to hold it harmless from such claims and attendant costs;
- The variance process is subject to public access under the TSSA Access and Privacy Code (available upon request). The fact that a variance has been granted, and information about any public conditions, such as a requirement to post a sign, may be released on request. Subject to law and the TSSA Access and Privacy Code, proprietary information will not be subject to release;
- The applicant shall pay the fee associated with the review of the variance; and
- A copy of the variance letter shall always be kept readily available and permanently legible in the vicinity of the appliance/equipment.

This variance only relates to the Act and regulations made thereunder and does not exempt you from compliance with other applicable regulatory requirements. The installation will be subject to an inspection to ensure compliance with the terms of the variance. Please contact Mike Sanford at 705-269-1269 to arrange for the inspection.

Should you have any questions or require further assistance, please contact John Guan at 416-734-3464, or by e-mail at jguan@tssa.org . When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,



John R. Marshall
Director, Fuels Safety Program

c. Mike Sanford, TSSA, msanford@tssa.org