

AMENDED ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 5578-BPBU2N
Issue Date: June 29, 2020

Parkbridge Lifestyle Communities Inc.
690 River Road West
Wasaga Beach, Ontario
L9Z 2P1

Site Location: Lonesome Pine Resort
2346 Pigeon Lake Road
City of Kawartha Lakes,
K0M 1A0

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

sewage works for the treatment and subsurface disposal of domestic sewage at a daily sanitary sewage flow of 93,800 litres per day, designed for a maximum balanced daily sewage flow of 60,000 litres per day, to service the Lonesome Pine Park Resort consisting of 298 trailer sites, seasonally operated (from May to October), located at above noted Site Location, consisting of the following:

Proposed Works:

Flow-Meter

- one (1) 50 millimeters diameter magnetic flow-meter housed in a pre-cast concrete flow-meter chamber upstream of the raw sewage pump station described below;

Raw Sewage Pump Station

- one (1) raw sewage pump station receiving sewage flow from the trailer sites and interconnected to the flow equalization tanks described below, consisting of a pre-cast concrete wet well (1.2 metres X 1.2 metres X 4.2 metres), equipped with timer- controlled duplex 1 HP sewage pumps, rated at 2.3 litres per second at 6.2 metres total dynamic head (TDH), complete with audible and visual high-level alarm system, dosing sewage to the septic tanks on an alternating basis at a rate of 625 litres per pump cycle;

Flow Equalization Tanks

- three (3) pre-cast concrete flow equalization tanks each with a capacity of 50,000 litres and inter-connected at the bottom to the raw sewage pump station described above;

Septic Tank

- one (1) single chambered septic tank (Septic Tank 1N) with capacity of 12,500 litres, complete with effluent filters, receiving effluent from the existing interconnected septic tanks (Septic Tanks 1K, 1L and 1M) described below and discharging to an effluent dosing station described below;

Effluent Dosing Station

- one (1) pre-cast concrete effluent dosing station, equipped with duplex 1 HP sewage pumps, with an operating range of 2.6 litres per second at 22.5 metres TDH to 5.0 litres per second at 12.5 metres TDH, complete with an audible and visual high-level alarm system, receiving effluent from Septic Tank 1N described above and distributing effluent to the twelve (12) existing leaching beds described below and three (3) proposed Enviro-Septic beds described below on a rotating basis;

Sub-surface Treatment and Disposal System

Q = 12,000 litres per day

- three (3) proposed Enviro-Septic System, each consisting of four (4) runs of Enviro-Septic pipes, each approximately 24.6 metres long per row, for a total length of approximately 98.4 metres in each Enviro-Septic System, rows to be spaced at 3.0 metres on centre lines and connected to venting system; the Enviro-Septic pipes to be a 300 millimetre diameter, high density plastic which is corrugated and perforated, and to be installed in an approved Enviro-Septic System Sand within a contact area of 351 square metres (26.4 metres by 13.3 metres) per each disposal bed; Enviro-Septic pipes, system sand and other components of the Enviro-Septic System must meet all requirements as per BMEC Authorization No. 18-05-386.

Existing Works:

Sewage System No. 1

Existing sub-surface disposal system, servicing 232 trailer sites, and consisting of;

Septic Tanks:

- three (3) interconnected septic tanks (Septic Tanks 1K, 1L and 1M), each with capacity of 36,000 litres equipped with baffles, inlet and outlet piping, and access risers, duplex effluent dosing pumps installed in the second chamber of Septic Tank 1M (to be removed), discharging effluent to leaching beds described below via distribution valve chambers;

Sub-surface Sewage Disposal System:

Q = 48,000 litres per day

- a leaching bed system consisting total of 12 leaching beds (Leaching Beds 1A, 1B, 1C, 1D, 1E, 1F, 1G, 1H, 1I, 1J, 1K and 1M), out of which 8 leaching beds each have ten (10) runs of 20 m length perforated pipe, 3 leaching beds each have eight (8) runs of 25 m length perforated pipe; and 1 leaching bed has fourteen (14) runs of 14.3 m length perforated pipe; all located over a mantle with total area of 8,000 m²

Existing Works (to be decommissioned):

Sewage System No. 1

Septic Tanks:

- ten (10) septic tanks of unknown capacity where Septic Tanks 1A, 1B, 1C, 1D, 1E, 1F, 1G, 1H and 1J are to be decommissioned and Septic Tank 1I is to be converted to a lift station;

Sewage System No. 2

Existing sub-surface disposal system, servicing 30 trailer sites, and consisting of;

Septic Tanks:

- three (3) septic tanks (Septic Tanks 2A to 2C) of unknown capacity, all collecting wastewater from the above-mentioned trailer sites and discharging to leaching bed described below;

Sub-surface Sewage Disposal System:

- one (1) leaching bed (Leaching Bed No. 2), consisting of an unknown length of absorption trench;

Note: The sewage from Sewage System No. 2 to be redirected to Sewage System No. 1.

Sewage System No. 3

Existing sub-surface disposal system, servicing 10 trailer sites, and consisting of;

Septic Tank:

- one (1) septic tank (Septic Tank 3A) of unknown capacity, collecting wastewater from the above-mentioned trailer sites and discharging to leaching bed described below;

Sub-surface Sewage Disposal System:

- one (1) leaching bed (Leaching Bed No. 3), consisting of an unknown length of absorption trench;

Note: The sewage from Sewage System No. 3 to be redirected to Sewage System No. 1.

Sewage System No. 4

Existing sub-surface disposal system, servicing 8 trailer sites, and consisting of;

Septic Tank:

- one (1) septic tank (Septic Tank 4A) of unknown capacity, collecting wastewater from the above-mentioned trailer sites and discharging to leaching bed described below;

Sub-surface Sewage Disposal System:

- one (1) leaching bed (Leaching Bed No. 4), consisting of an unknown length of absorption trench;

Note: The sewage from Sewage System No. 4 to be redirected to Sewage System No. 1.

Sewage System No. 5

Existing sub-surface disposal system, servicing 18 trailer sites, and consisting of;

Septic Tank:

- one (1) septic tank (Septic Tank 5A) of unknown capacity, collecting wastewater from the above-mentioned trailer sites and discharging to leaching bed described below;

Sub-surface Sewage Disposal System:

- one (1) leaching bed (Leaching Bed No. 5), consisting of an unknown length of absorption trench;

Note: The sewage from Sewage System No. 5 to be redirected to Sewage System No. 1.

Holding Tanks:

- two (2) holding tanks of unknown capacity (HT1 and HT2);

all other controls, electrical equipment, instrumentation, piping, pumps, valves and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with Supporting Documentation submitted to the Ministry as listed in the **Schedule A** in this Approval.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this entire Approval document and any Schedules to it, including the application and Supporting Documentation;
2. "BOD₅" (also known as TBOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;
3. "CBOD₅" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
4. "Director" means a person appointed by the Minister pursuant to Section 5 of the EPA for the purposes of Part II.I of the EPA;
5. "District Manager" means the District Manager of the appropriate local district office of the Ministry where the Works is geographically located;
6. "Grab Sample" means an individual sample of at least 1000 millilitres collected in an appropriate container at a randomly selected time over a period of time not exceeding 15 minutes;

7. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c.E.19, as amended;
8. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
9. "Licensed Installer" means a person who is registered under the OBC to construct, install, repair, service, clean or empty on-site sewage systems;
10. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
11. "OBC" means the Ontario Building Code;
12. "Owner" means Parkbridge Lifestyle Communities Inc., and its successors and assignees;
13. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
14. "Professional Engineer" means a person entitled to practice as a Professional Engineer in the Province of Ontario under a licence issued under the *Professional Engineers Act*;
15. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
16. "Supporting Documentation" means the documents listed in Schedule A of this Approval;
17. "Works" means the approved sewage works, and includes Proposed Works, and Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. Except as otherwise provided by these conditions, the Owner shall design, build, install, operate and maintain the Works in accordance with the description given in this Approval, and the application for approval of the Works.
3. Where there is a conflict between a provision of any document in the schedule referred to in this Approval and the conditions of this Approval, the Conditions in this Approval shall take precedence,

and where there is a conflict between the documents in the schedule, the document bearing the most recent date shall prevail.

4. Where there is a conflict between the documents listed in the Schedule submitted documents, and the application, the application shall take precedence unless it is clear that the purpose of the document was to amend the application.
5. The Conditions of this Approval are severable. If any Condition of this Approval, or the application of any requirement of this Approval to any circumstance, is held invalid or unenforceable, the application of such condition to other circumstances and the remainder of this Approval shall not be affected thereby.
6. The issuance of, and compliance with the conditions of, this Approval does not:
 - a. relieve any person of any obligation to comply with any provision of any applicable statute, regulation or other legal requirement, including but not limited to, the obligation to obtain approval from the local conservation authority necessary to construct or operate the sewage works; or
 - b. limit in any way the authority of the Ministry to require certain steps be taken to require the Owner to furnish any further information related to compliance with this Approval.

2. EXPIRY OF APPROVAL

1. This Approval will cease to apply to those parts of the Works which have not been constructed within five (5) years of the date of this Approval.

3. CHANGE OF OWNER

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within thirty (30) days of the change occurring:
 - a. change of Owner;
 - b. change of address of the Owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act*, R.S.O. 1990, c.B17 shall be included in the notification to the District Manager;
 - d. change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the *Corporations Informations Act*, R.S.O. 1990, c. C39 shall be included in the notification to the District Manager;
2. In the event of any change in ownership of the Works, other than a change to a successor

municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.

3. The Owner shall ensure that all communications made pursuant to this condition refer to the environmental compliance approval number.

4. CONSTRUCTION

1. The Owner shall ensure that the construction of the Works is supervised by a licensed installer or a Professional Engineer, as defined in the *Professional Engineers Act* .
2. The Owner shall ensure that the Enviro-Septic System is installed in accordance with the manufacturer's installation manual.
3. The Owner shall ensure that the Works are constructed such that minimum horizontal clearance distances as specified in the OBC are satisfied.
4. Upon construction of the Works, the Owner shall prepare a statement, certified by a Professional Engineer, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
5. Upon construction of the Works, the Owner shall prepare a set of as-built drawings showing the works "as constructed". "As-built" drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the site for the operational life of the Works and shall be made available for inspection by Ministry staff.

5. EFFLUENT OBJECTIVES

1. The Owner shall use best efforts to design, construct and operate the Works with the objective that the concentrations of the materials named as effluent parameters in the Effluent Objectives Table included in **Schedule B** are not exceeded in the effluent from the Works.
2. For the purposes of subsection (1):
 - a. The concentrations of CBOD₅ and TSS named in Column 1 of Effluent Objectives Table listed in Schedule B, as measured at each monitoring event, should be compared to the corresponding concentration set out in Column 2 of Effluent Objectives Table listed in **Schedule B**.
3. In the event of an exceedance of the objective set out in subsection (1), the Owner shall,
 - a. notify the District Office as soon as possible during normal working hours,
 - b. take immediate action to identify the source of the sewage works failure, and
 - c. take immediate action to prevent further exceedance.

4. The Owner shall include in all reports submitted in accordance with Condition 8, a summary of the efforts made and results achieved under this condition.

6. MONITORING AND RECORDING

The Owner shall, upon commencement of operation of the Works, carry out the following monitoring program:

1. All samples and measurements taken for the purposes of this Approval are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
2. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Effluent Monitoring Table included in Schedule B.
3. GROUND WATER MONITORING PROGRAM:
 - a. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Groundwater Monitoring Table included in Schedule B.
4. The Owner shall employ measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal system, including but not limited to water/wastewater flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal system.
5. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
 - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended from time to time by more recently published editions;
 - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater Version 2.0" (January 2016), PIBS 2724e02, as amended;
 - c. the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition), as amended from time to time by more recently published editions.
6. The Owner shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

7. The Owner shall maintain a logbook to record the results of Operation and Maintenance activities specified in the above subclauses, and shall keep the logbook at the site and make it available for inspection by the Ministry staff.

7. OPERATIONS AND MAINTENANCE

1. The Owner shall ensure that at all times, the Works and related equipment and appurtenances which are installed or used to achieve compliance with this Approval are properly operated and maintained as required per the operation and maintenance manual.
2. The Owner shall prepare an operations manual within six (6) months of the introduction of sewage to the Works, that includes, but not necessarily limited to, the following information:
 - a. operating procedures for routine operation of all the Works;
 - b. inspection programs, including frequency of inspection, for all the Works and the methods or tests employed to detect when maintenance is necessary;
 - c. repair and maintenance programs, including the frequency of repair and maintenance for all the Works; copies of maintenance contracts for any routine inspections & pump-outs should be included for all the tanks and treatment units;
 - d. procedures for the inspection and calibration of monitoring equipment;
 - e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the District Manager; and
 - f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
3. The Owner shall maintain the operations manual current and retain a copy at the location of the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
4. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
5. The Owner shall ensure that grass-cutting is maintained regularly over all the subsurface disposal beds, and the surface of the bed(s) are visually observed on a monthly basis. In the event a break-out is observed from a subsurface disposal bed, the Owner shall ensure that the sewage discharge to the bed is discontinued and the incident immediately reported verbally to the District Manager, followed by a written report within one (1) week. The Owner shall ensure that during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to a

surface water body or to the environment, and shall be safely collected and disposed off through a licensed waste hauler to an approved waste disposal site.

6. The Owner shall ensure that adequate steps are taken to ensure that the area of the Works are protected from all forms of vehicle traffic.
7. The Owner shall employ for the overall operation of the Works a person who possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.

8. REPORTING

1. One week prior to the start up of the operation of the Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
2. In addition to the obligations under Part X of the EPA , the Owner shall, within 10 working days of the occurrence of any reportable spill as defined in Ontario Regulation 675/98, loss of any product, by-product, intermediate product, oil, solvent, waste material or any other polluting substance into the environment, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill or loss, clean-up and recovery measures taken, preventative measures to be taken and schedule of implementation.
3. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
4. The Owner shall prepare and submit a performance report, on an annual basis, within ninety (90) days following the end of each operational season to the District Manager. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
 - a. a tabulation of the daily volumes of effluent disposed through each of the subsurface disposal system during the reporting period including an overview of the success and adequacy of the Works;
 - b. a summary and interpretation of groundwater monitoring data with respect to Reasonable Use and any impacts on Pigeon Lake;
 - c. a review and assessment of performance of Works, including all treatment units and disposal beds;
 - d. a description of any operating problems encountered and corrective actions taken at all sewage Works located at the property;
 - e. a record of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of all Works located at the property' including but not

limited to: records of maintenance inspections for the treatment system, records of septic tank effluent filters cleaning, records of septic tank pump-outs, records of sludge pump-outs accumulated from the treatment system, records of visual inspections of all disposal systems;

- f. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
- g. a summary and interpretation of all daily flow data and results achieved in not exceeding the maximum daily sewage flow discharged into each one of the subsurface disposal system;
- h. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
- i. a summary of all spill or abnormal discharge events;
- j. any other information the District Manager requires from time to time;

9. DECOMMISSIONING OF UN-USED SEWAGE WORKS

1. The Owner shall properly abandon any portion of unused existing sewage Works, as directed below, and upon completion of decommissioning report in writing to the District Manager.
 - a. any sewage pipes leading from building structures to unused sewage Works components shall be disconnected and capped;
 - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
 - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes;

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.

2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
4. Condition 4 is included to ensure that the works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
5. Condition 5 is imposed to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
6. Condition 6 is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives specified in the Approval and that the Works does not cause any impairment to the receiving watercourse.
7. Condition 7 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected. As well, the inclusion of an operations manual, maintenance agreement with the manufacturer for the treatment process/technology and a complete set of "as constructed" drawings governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the Ministry. Such information is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the work.
8. Condition 8 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.
9. Condition 9 is included to ensure that any components of un-used Works are properly decommissioned.

Schedule A

1. Application for Approval of Sewage Works submitted by Eric Watkin, C.E.T., of Tatham Engineering Limited, and signed by Jason Krynicky, Director, Environmental Operations, dated July 25, 2019, including design report, final plans, specifications and all supporting documentation and correspondence submitted in support of this application.

Schedule B

Effluent Monitoring Table

Sampling Location	each Enviro-Septic System
Frequency	twice during operating season
Sample Type	Grab
Parameters	CBOD ₅ Total Suspended Solids (TSS) Total Phosphorus (TP)

Groundwater Monitoring Table

Sampling Location	Existing monitoring wells GW1, GW2 and GW3 Three (3) new monitoring wells to be installed; one downgradient of proposed Enviro-Septic Systems (GW4), one downgradient of existing trenches (GW5) and one downgradient of GW4, close to northeastern property boundary (GW6)
Frequency	twice during operating season
Sample Type	Grab
Parameters	Total (Ammonia + Ammonium) Nitrogen Nitrate- Nitrogen Nitrite-Nitrogen Total Phosphorus (TP) * Chloride Sodium Iron pH Alkalinity

* Total Phosphorus samples should be field filtered and acidified.

Effluent Objectives Table

Effluent Objectives (Samples to be collected from each Enviro-Septic System)	
Effluent Parameter	Objective Concentration (milligrams per litre unless otherwise indicated)
Column 1	Column 2
CBOD ₅	10
Total Suspended Solids	10

**Upon issuance of the environmental compliance approval, I hereby revoke Approval No(s).
0290-65GQUG issued on June 24, 2005**

In accordance with Section 139 of the Environmental Protection Act, you may by written Notice served upon me and the Environmental Review Tribunal within 15 days after receipt of this Notice, require a hearing by the Tribunal. Section 142 of the Environmental Protection Act provides that the Notice requiring the hearing shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

Pursuant to subsection 139(3) of the Environmental Protection Act, a hearing may not be required with respect to any terms and conditions in this environmental compliance approval, if the terms and conditions are substantially the same as those contained in an approval that is amended or revoked by this environmental compliance approval.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5


AND

The Director appointed for the purposes of Part II.1 of
the Environmental Protection Act
Ministry of the Environment, Conservation and Parks
135 St. Clair Avenue West, 1st Floor
Toronto, Ontario
M4V 1P5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 29th day of June, 2020



Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the
Environmental Protection Act

SP/

c: District Manager, MECP Peterborough District Office
Eric Watkin, C.E.T., L.E.L., Tatham Engineering Limited