

Content Copy Of Original



Ministry of the Environment, Conservation and Parks
Ministère de l'Environnement, de la Protection de la nature et des Parcs

**AMENDMENT TO RENEWABLE ENERGY APPROVAL
NUMBER 3116-AWEQUG
Issue Date: August 13, 2020**

Pendleton Energy Centre GP Inc., as general partner for and on behalf of
Pendleton Energy Centre Limited Partnership
53 Jarvis St, No. 300
Toronto, Ontario
M5C 2H2

Site Location: Pendleton Solar Energy Centre
830 County Road 19, Curran, Ontario
Lot 19 and 20, Concession 8
Alfred and Plantagenet Township, United Counties of Prescott and Russell

You are hereby notified that I have amended Approval No. 3116-AWEQUG issued on April 3, 2018 for a Class 3 solar facility, as follows:

A. The definition of "Application" is deleted and replaced with the following:

7. "Application" means the application for a Renewable Energy Approval dated October 20, 2018, and signed by Stephane Desdunes, Director, Pendleton Energy Centre GP Inc., as general partner for and on behalf of Pendleton Solar Centre Limited Partnership, and all supporting documentation submitted with the application, including amended documentation submitted up to March 29, 2018; and as further amended by the application for an amendment to the Renewable Energy Approval dated August 21, 2019, and signed by Alex Couture, Regional Senior Director Canada, on behalf of Pendleton Energy Centre GP Inc., as general partner for and on behalf of Pendleton Energy Centre Limited Partnership, and all supporting documentation submitted with the application, including amended information submitted up to June 23, 2020;

B. Condition G of the Approval is deleted.

C. Schedule A of the Approval is deleted and replaced with the following:

**SCHEDULE A
Facility Description**

1. The Facility shall consist of the construction, installation, operation, use and retiring of the following:

(a) Up to six (6) inverter clusters within arrays of photovoltaic (PV) modules consisting of one (1) 2.0 megawatt (MW) inverter and one (1) 2.5 megavolt-ampere (MVA) transformer.

(b) Associated ancillary equipment, systems and technologies including, but not limited to, on-site access roads, below and above grade cabling, and below and above grade distribution and transmission lines.

2 The location of any temporary laydown areas, interior access roads, entrances to the site, underground or overhead distribution or transmission lines, and other project components associated with the Facility, excluding the Equipment, may be altered or moved from the locations specified in the Application, provided that:

(a) proposed modifications to the project are all within the already-assessed Project Location;

(b) all setback prohibitions established under O. Reg. 359/09 are complied with;

(c) the appropriate ministries have been consulted, including the Ministry of Natural Resources and Forestry and the Ministry of Heritage, Sport, Tourism and Culture Industries, as applicable;

(d) any applicable revised report in respect of the proposed modifications, as well as a modifications document prepared in accordance with Chapter 10 of the Ministry of the Environment and Climate Change publication "Technical Guide to Renewable Energy Approvals", 2017, as amended, is prepared and submitted to the Director; and

(e) no modifications to the project occurs until the Director provides written approval of the proposed modifications in the form of a letter.

3. The Company shall follow any and all directions provided to the Director in respect of project modifications proposed pursuant to Item 2 of Schedule A.

all in accordance with the Application.

D. Schedule B, Table B1 of the Approval is deleted and replaced with the following:

Table B1: Coordinates of the Allowable Polygon for the Equipment and Noise Specifications

Coordinates of the Polygon are listed below in UTM, Z18-NAD83 projection:

Source ID	Sound Power Level (dBA)	Easting (m)	Northing (m)	Source Description
inv_01	92	494439 494390 494724 494734	5035324 5035456 5035569 5035408	Inverter 1, see Table B2 below
inv_02	92	494488 494439 494734 494745	5035197 5035324 5035408 5035254	Inverter 2, See Table B2 below
inv_03	92	494563 494488	5034996 5035197	Inverter 3, See Table B2 below

		494745 494757	5035254 5035069	
inv_04	92	494757 494745 495079 495125	5035069 5035254 5035329 5035208	Inverter 4, See Table B2 below
inv_05	92	494745 494734 495019 495079	5035254 5035408 5035488 5035329	Inverter 5, See Table B2 below
inv_06	92	494734 494724 494950 495019	5035408 5035563 5035671 5035488	Inverter 6, See Table B2 below
trans_01	82	494439 494390 494724 494734	5035324 5035456 5035569 5035408	Inverter Transformer 1, See Table B3 below
trans_02	82	494488 494439 494734 494745	5035197 5035324 5035408 5035254	Inverter Transformer 2, See Table B3 below
trans_03	82	494563 494488 494745 494757	5034996 5035197 5035254 5035069	Inverter Transformer 3, See Table B3 below

Table B1: Coordinates of the Allowable Polygon for the Equipment and Noise Specifications

Coordinates of the Polygon are listed below in UTM, Z18-NAD83 projection
(con't):

Source ID	Sound Power Level (dBA)	Easting (m)	Northing (m)	Source Description
trans_04	82	494757 494745 495079 495125	5035069 5035254 5035329 5035208	Inverter Transformer 4, See Table B3 below
trans_05	82	494745 494734 495019 495079	5035254 5035408 5035488 5035329	Inverter Transformer 5, See Table B3 below

trans_06	82	494734	5035408	Inverter Transformer 6, See Table B3 below
		494724	5035563	
		494950	5035671	
		495019	5035488	

E. Schedule B, Table B4 of the Approval is deleted.

All other Terms and Conditions of the Approval remain the same.

This Notice shall constitute part of the approval issued under Approval No. 3116-AWEQUG dated April 3, 2018

In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Minister of the Environment, Conservation and Parks, require a hearing by the Tribunal.

In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Minister of the Environment, Conservation and Parks will place notice of your request for a hearing on the Environmental Registry.

Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:

- a. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The signed and dated notice requiring the hearing should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The renewable energy approval number;
4. The date of the renewable energy approval;
5. The name of the Director;
6. The municipality or municipalities within which the project is to be engaged in;

This notice must be served upon:

The Secretary*
Environmental Review
Tribunal
655 Bay Street, 15th Floor
Toronto, Ontario
M5G 1E5

AND

The Minister of the
Environment, Conservation
and Parks
777 Bay Street, 5th Floor
Toronto, Ontario
M7A 2J3

AND

The Director
Section 47.5, Environmental
Protection Act
Ministry of the Environment,
Conservation and Parks
135 St. Clair Avenue West, 1st Floor

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when this period ends.

Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.

DATED AT TORONTO this 13th day of August,
2020

Bahar Aminvaziri, P.Eng.
Director
Section 47.5, *Environmental
Protection Act*

SR/
c: Area Manager, MECP Cornwall
c: District Manager, MECP Ottawa
Rob Nadolny, Stantec Consulting Ltd.