



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

May 20, 2021

CRAIG CAMERON
K+S WINDSOR SALT LTD
200 MORTON DR
WINDSOR ON N9J 3W9

craigcameron@windsorsalt.com

FS-LF Variance
Service Request No.: 3026828
Fuels Safety Private Fuel Outlet - Self Serve
Installed at: 200 MORTON DR WINDSOR

Dear CRAIG CAMERON,

Re: Application for a Variance from Clause 1.3.1 of the Liquid Fuels Handling Code, O. Reg. 217/01

This is in response to your variance application for the above location.

Your variance request was to use a FloMAX dry-break style fuelling nozzle to fuel mining equipment (e.g. front-end loaders) at the Windsor Salt Mines. The FloMAX dry-break style fuelling nozzle is not certified in accordance with the Underwriters Laboratories of Canada (CAN/ULC) S-620:2016 Standard in contravention of clause 1.3.1 of the Liquid Fuels Handling Code.

Please be advised that your variance application has been approved because the mining equipment is equipped with 1.5-inch dry-break style connections suitable for use with FloMAX nozzles. The fill system is designed so that the nozzle will stop automatically when the tank reaches its intended fill level. This is a standard fill system used by major construction/mining equipment manufacturers around the world. Fill connections for these tanks are located below the top of the tank at a safe and convenient height for the operator. There are no alternative fill locations or fill methods for these fuel tanks. The FloMAX nozzle has a flow rate of up to 150 GPM, which is compatible with the 1.5-inch dry-break style connections on mining equipment, compared to a flow rate of approximately 60 GPM for conventional one-inch nozzles. Productivity is increased by reducing time spent refuelling equipment.

In support of the variance request, you have submitted a letter signed by Pat Schryver, P.Eng. (Ontario) and a report signed by John Peters, P.Eng. (Alberta), comparing the FloMAX nozzle to CAN/ULC-S620:2016. John Peters has recommended that the FloMAX FNLB Fuel nozzle be granted equivalency with valves certified to the CAN/ULCS620:2016 Standard.

Pat Schryver has reviewed John Peters' report and agrees that the FloMAX FNLB fuel nozzle should be granted equivalency with valves certified to the CAN/ULCS620:2016 Standard, the standard for hose nozzle valves for flammable and combustible liquids for use with mining equipment.

Your variance request is approved.

Please be advised that this variance will not take effect until 15 days from the date of posting the decision on the environmental registry. This decision of the Director is subject to a right of appeal, under the Environmental Bill of Rights, if such an appeal is filed within 15 days from date of posting. In the event an appeal is filed, this decision of the director may be subsequently stayed, disallowed or significantly altered. Notice of an appeal will be placed on the Environmental Bill of Rights registry.

This variance is allowed under the authority of subsection 36.(3)(c) of the *Technical Standards and Safety Act, 2000*, (the "Act") and subject to such conditions as may be specified herein, being that:

- The installation/system/appliance dealt with in this variance must be inspected and may be periodically audited by TSSA. Please contact John Stewart at 226-229-2099 or by email at jstewart@tssa.org to arrange for the initial inspection;
- Non-conformity with the conditions specified shall thereby cause the allowed variance to become null and void;
- The applicant accepts full responsibility for any and all damages resulting from the use of the thing to which the variance applies. The applicant further accepts full responsibility for any impacts to the health and safety of any person in consequence of the allowance of the variance or of non-conformity with the conditions specified. The Technical Standards and Safety Authority accepts no responsibility for any such damages or impacts;
- In the event of any claims against the Technical Standards and Safety Authority arising from allowance of the variance or non-conformity with the conditions specified, the applicant agrees to indemnify the Technical Standards and Safety Authority and agrees to hold it harmless from such claims and attendant costs;
- The variance process is subject to public access under the TSSA Access and Privacy Code (available upon request). The fact that a variance has been granted and information about any public conditions, such as a requirement to post a sign, may be released on request. Subject to law and the TSSA Access and Privacy Code, proprietary information will not be subject to release;
- The applicant shall pay the fee associated with the review of the variance; and
- A copy of the variance letter shall always be kept readily available and permanently legible in the vicinity of the appliance/equipment.

This variance only relates to the Act and regulations made thereunder and does not exempt you from compliance with other applicable regulatory requirements. The installation may be subject to an inspection to ensure compliance with the terms of the variance.

Should you have any questions or require further assistance, please contact Ann-Marie Barker at 416-734-3354 or by email at abarker@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Zenon Fraczkowski

Zenon J. Fraczkowski, P. Eng.
Manager, Fuels Safety Engineering
Delegated Authority under section 36(3) (c) of TSS Act

c: El-Cheikh, Abdulrahman, Windsor Salt (AEI-Cheikh@windsorsalt.com)
Rick Palamaruk, Scott Pump Service (Rick.Palamaruk@scottpumpservice.com)
John Stewart, TSSA (jstewart@tssa.org)
Kevin Abbott, TSSA (kabbott@tssa.org)

<p>A legible copy of this letter shall be kept readily available near the appliance/equipment. This variance is not valid unless all variance conditions in this letter have been met.</p>
--