

**ENVIRONMENTAL COMPLIANCE APPROVAL**

NUMBER 6283-CCEMST  
Issue Date: April 21, 2022

AON Inc.  
307 Aylmer St  
Post Office Box, No. 296  
Peterborough, Ontario  
K9J 7M4

Site Location: Port Hope Golf and Country Club  
82 Victoria St S  
Municipality of Port Hope, County of Northumberland,  
Ontario  
L1A 3L6

*You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:*

sewage works for the treatment and subsurface disposal of domestic sewage, with a combined total daily sanitary sewage design flow of **26,130 litres per day** to service a proposed Restaurant and the existing Beige House, Pool House, Pro Shop, Green House, Brick House and Banquet Hall, all located at the above site location, consisting of the following:

**PROPOSED WORKS**

**Restaurant Sewage System**

**Q = 15,500 litres per day**

- one (1) in-ground 7,000 litre 3-compartment precast concrete oil & grease interceptor (Brooklin Concrete Model 155 or Equivalent Equipment), located immediately northeast of the proposed 124-seat Restaurant building (originally the Farm House), receiving raw sewage from kitchen sinks and floor drains of the building and discharging effluent via gravity to the septic tanks described below;
- two (2) in-ground 22,000 litre 2-compartment precast concrete septic tanks connected in series with the outlet of the second septic tank equipped with an effluent filter meeting the OBC requirements, located immediately downstream of the oil & grease interceptor, receiving the oil & grease interceptor effluent and raw sanitary sewage from the rest of the building fixtures, and discharging effluent via gravity to the provisional advanced treatment unit / balancing tank

described below;

- one (1) provisional advanced treatment unit (Infiltrator Ecopods or Equivalent Equipment), to be located between the septic tanks and the balancing tank and to be installed if required for improving influent sewage quality for downstream treatment processes in accordance with Condition 5.3;
- one (1) 7,000 litre single compartment precast concrete balancing tank, equipped with a high level audible/visual alarm, floats and two (2) timer controlled submersible effluent pumps (Little Giant WS Series 1/2 HP or Equivalent Equipment) programmed to time dose 1,833 litres every 4 hours (maximum 11,000 litres per day), discharging effluent to the Infiltrator Advanced Treatment Leachfield (ATL) System described below via a 50 millimetre diameter forcemain;
- one (1) Infiltrator ATL System having a treatment capacity of 11,000 litres per day, comprising eighteen (18) rows of eight (8) conduits (144 conduits in total) evenly spaced at 900 millimetres between each row, with six (6) rows on the first level and remaining twelve (12) rows terraced (two rows per level with a maximum ground slope of 4:1), constructed in 230 millimetres or more thick specified system sand (ASTM C33) overlaying native soil with a percolation rate of 20 minutes per centimetre and covering a minimum area of 708.66 square metres (27.9 metres by 25.4 metres), equipped with a sampling device, all conforming to the requirements of BMEC Authorization No. 18-03-384;

### **Beige House Sewage System**

**Q = 1,600 litres per day**

- one (1) in-ground 3,600 litre 2-compartment precast concrete septic tank equipped with an effluent filter meeting the OBC requirements, located immediately northwest of the Beige House, receiving raw sanitary sewage from the 3-bedroom dwelling and discharging effluent via gravity to the pump tank described below;
- one (1) 700 litre single compartment pump tank equipped with a high level audible/visual alarm, floats and one (1) effluent pump (Little Giant WS Series 1/3 HP or Equivalent Equipment) with the pump float set to discharge 267 litres per dose on-demand within a fifteen minute period (maximum 1,600 litres per day), discharging to the Infiltrator ATL System described below via a 50 millimetre diameter forcemain;
- one (1) Infiltrator ATL System having a treatment capacity of 1,600 litres per day, comprising five (5) rows of four (4) conduits (20 conduits in total) evenly spaced at 1,000 millimetres between each row, constructed in 230 millimetres or more thick specified system sand (ASTM C33) overlaying native soil with a percolation rate of 20 minutes per centimetre and covering a minimum area of 83.2 square metres (12.8 metres by 6.5 metres), equipped with a sampling device, all conforming to the requirements of BMEC Authorization No. 18-03-384;

### **Pool House Sewage System**

**Q = 1,000 litres per day**

- one (1) in-ground 3,600 litre 2-compartment precast concrete septic tank equipped with an

effluent filter meeting the OBC requirements, located immediately east of the Pool House, receiving raw sanitary sewage from the building and discharging effluent via gravity to the pump tank described below;

- one (1) 700 litre single compartment pump tank equipped with a high level audible/visual alarm, floats, and one (1) effluent pump (Little Giant WS Series 1/3 HP or Equivalent Equipment), discharging to the proposed filter bed described below via a 50 millimetre diameter forcemain;
- one (1) above-ground filter bed having an effective area of 20.4 square metres (6.8 metres by 3.0 metres), consisting of four (4) runs of 6.1 metre long 75 millimetre diameter perforated distribution piping, installed in a 300 millimetre deep layer of clear stone over a minimum of 750 millimetre deep filter medium meeting the grading requirements as per the OBC, and having a base contact area of 32.0 square metres (8.0 metres by 4.0 metres) between the filter medium and the underlying soil mantle composed of imported sand fill with a percolation time T of 6 to 10 minutes per centimetre, extending at least over 15 metres beyond the outer distribution piping in the direction in which the effluent from the filter bed will move laterally;

## **EXISTING WORKS**

### **Pro Shop Sewage System**

**Q = 1,900 litres per day**

- one (1) 7,580 litre 2-compartment precast concrete septic tank, to be upgraded with an effluent filter meeting the OBC requirements and replacement access risers to ground surface, located immediately west of the Pro Shop, receiving raw sanitary sewage from the building and discharging effluent via gravity to the pump tank described below;
- one (1) 1,600 litre single compartment pump tank, to be upgraded with a high level audible/visual alarm, equipped with one (1) effluent pump and discharging to the existing conventional absorption trench leaching bed described below via a forcemain;
- one (1) in-ground conventional absorption trench leaching bed, consisting of twelve (12) runs of 21.33 metre long distribution piping (approximately 256 metres in total);

### **Green House Sewage System (Permit Hop-2-96)**

**Q = 1,100 litres per day**

- one (1) 3,600 litre 2-compartment precast concrete septic tank, to be upgraded with an effluent filter meeting the OBC requirements and replacement access risers to ground surface, located immediately south of the Green House, receiving raw sanitary sewage from the 2-bedroom dwelling and discharging effluent via gravity to the existing filter bed described below;
- one (1) filter bed, having an effective area of approximately 37 square metres (6.1 metres by 6.1 metres) and a total disposal area of approximately 100 square metres (10 metres by 10 metres);

**Brick House Sewage System (Permit Hop-8-98)**

**Q = 1,100 litres per day**

- one (1) 3,600 litre 2-compartment precast concrete septic tank, to be upgraded with an effluent filter meeting the OBC requirements and replacement access risers to ground surface, located immediately south of the Brick House, receiving raw sanitary sewage from the 2-bedroom dwelling and discharging effluent via gravity to the existing conventional absorption trench leaching bed described below;
- one (1) conventional absorption trench leaching bed, consisting of five (5) runs of 15 metre long distribution piping (approximately 75 metres in total);

**Banquet Hall Sewage System (Permit Hop-8-95)**

**Q = 3,930 litres per day**

- one (1) 12,000 litre 2-compartment precast concrete septic tank, to be upgraded with an effluent filter meeting the OBC requirements and replacement access risers to ground surface, located immediately northeast of the Banquet Hall building, receiving raw sanitary sewage from the 131-seat banquet hall and discharging effluent via gravity to the pump tank described below;
- one (1) single compartment pump tank with an unknown capacity, to be upgraded with a high level audible/visual alarm, equipped with one (1) effluent pump and discharging to the existing conventional absorption trench leaching bed described below via a forcemain;
- one (1) conventional absorption trench leaching bed, consisting of five (5) runs of 24.672 metre long distribution piping (approximately 213.36 metres in total);

including all other controls, electrical equipment, instrumentation, piping, pumps, valves and appurtenances essential for the proper operation of the aforementioned sewage works;

all in accordance with the submitted supporting documents listed in **Schedule A**.

*For the purpose of this environmental compliance approval, the following definitions apply:*

1. "Approval" means this entire Approval document and any Schedules to it, including the application and Supporting Documentation;
2. "BOD<sub>5</sub>" (also known as TBOD<sub>5</sub>) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;
3. "CBOD<sub>5</sub>" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
4. "Director" means a person appointed by the Minister pursuant to Section 5 of the EPA for the purposes of Part II.I of the EPA;
5. "Grab Sample" or "Grab" means an individual sample of at least 1000 millilitres collected in an appropriate container at a randomly selected time over a period of time not exceeding 15 minutes;
6. "District Manager" means the District Manager of the Peterborough District Office;
7. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
8. "Equivalent Equipment" means a substituted equipment or like-for-like equipment that meets the required quality and performance standards of a named equipment;
9. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
10. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28;
11. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
12. "OBC" means the Ontario Building Code, Ontario Regulation 332/12 (Building Code) as amended to January 1, 2015, made under the *Building Code Act*, 1992, S.O. 1992, c. 23;
13. "Owner" means AON Inc. and its successors and assignees;
14. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
15. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;

16. "Works" means the approved sewage works, and includes Proposed Works, and Existing Works.

*You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:*

## **TERMS AND CONDITIONS**

### **1. GENERAL PROVISIONS**

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

### **2. EXPIRY OF APPROVAL**

1. This Approval will cease to apply to those parts of the Works which have not been constructed within **five (5) years** of the date of this Approval.

### **3. CHANGE OF OWNER**

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
  - a. change of address of Owner;
  - b. change of Owner, including address of new owner;
  - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act* , R.S.O. 1990, c.B17 shall be included in the notification to the District Manager;
  - d. change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the *Corporations Informations Act* , R.S.O. 1990, c. C39 shall be included in the notification to the District Manager;
2. In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this

Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.

#### 4. CONSTRUCTION

1. The Owner shall ensure that the construction of the Works is supervised by a Licensed Engineering Practitioner.
2. The Owner shall ensure that the Infiltrator Advanced Treatment Leachfield (ATL) Systems are installed in accordance with the Manufacturer's Installation Manual.
3. The Owner shall ensure that an imported soil that is required for construction of any subsurface disposal bed as per this Approval is tested and verified by the Licensed Engineering Practitioner for the percolation time (T) prior to delivering to the site location and the written records are kept at the site.
4. Upon construction of the Works, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
5. Upon construction of the Works, the Owner shall prepare a set of as-built drawings showing the works "as constructed". "As-built" drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the site for the operational life of the Works and shall be made available for inspection by Ministry staff.

#### 5. EFFLUENT OBJECTIVES

1. The Owner shall design and undertake everything practicable to operate the Works in accordance with the following objectives:
  - a. Final Effluent parameters design objectives listed in the table(s) included in **Schedule B**.
2. For the purposes of subsection (1):
  - a. The concentrations of CBOD5 and TSS named in Column 1 of the Effluent Objectives Table listed in **Schedule B**, as measured at each monitoring event, should be compared to the corresponding concentration set out in Column 2 of the Effluent Objectives Table listed in **Schedule B**.
3. The Owner shall implement the provisional advanced treatment unit (i.e., Infiltrator Ecopods or Equivalent Equipment) listed in this Approval in the event that,
  - a. the sampling results collected from the Balancing Tank of the Restaurant Sewage System in accordance with Condition 7 and **Schedule C** indicate that the strength of the influent is consistently higher than that of residential sewage (i.e., three

consecutive samples); and

- b. the sampling results collected from the Infiltrator ATL System sampling port of the Restaurant Sewage System in accordance with Condition 7 and **Schedule C** consistently exceed the Effluent Objectives listed in **Schedule B** (i.e., three consecutive samples).

## 6. OPERATIONS AND MAINTENANCE

1. The Owner shall ensure that, at all times, the Works and the related equipment and appurtenances used to achieve compliance with this Approval are properly operated and maintained. Proper operation and maintenance shall include effective performance, adequate funding, adequate staffing and training, including training in all procedures and other requirements of this Approval and the OWRA and regulations, adequate laboratory facilities, process controls and alarms and the use of process chemicals and other substances used in the Works.
2. The Owner shall prepare an operations manual within **six (6) months** of the introduction of sewage to the Works, that includes, but not necessarily limited to, the following information:
  - a. operating procedures for routine operation of all the Works;
  - b. inspection programs, including frequency of inspection, for all the Works and the methods or tests employed to detect when maintenance is necessary;
  - c. repair and maintenance programs, including the frequency of repair and maintenance for all the Works; copies of maintenance contracts for any routine inspections & pump-outs should be included for all the tanks and treatment units;
  - d. procedures for the inspection and calibration of monitoring equipment;
  - e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the Spills Action Centre (SAC) and District Manager; and
  - f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
4. The Owner shall, upon the construction, prepare and make available for inspection by Ministry staff, a maintenance agreement with the manufacturer for the treatment process/technology or its authorized agent. The maintenance agreement must be retained at the site and kept current for the



operational life of the Works.

5. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
6. The Owner shall ensure that the oil/grease interceptor is inspected and maintained on regular basis as required, and grease is disposed off site by a licensed hauler (e.g. at approved recycling sites).
7. The Owner shall ensure that grass-cutting is maintained regularly over the subsurface disposal bed(s), and that adequate steps are taken to ensure that the area of the underground works is protected from vehicle traffic.
8. The Owner shall visually inspect the general area where sewage works are located for break-out once every month during the operating season.
9. In the event a break-out is observed from a subsurface disposal bed, the Owner shall do the following:
  - a. sewage discharge to that subsurface disposal system shall be discontinued;
  - b. the incident shall be **immediately** reported verbally to the Spills Action Centre (SAC) at (416) 325-3000 or 1-800-268-6060;
  - c. submit a written report to the District Manager within **one (1) week** of the break-out;
  - d. access to the break-out area shall be restricted until remedial actions are complete;
  - e. during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to the environment; and
  - f. sewage generated at the site shall be safely collected and disposed of through a licensed waste hauler to an approved sewage disposal site.
10. The Owner shall employ for the overall operation of the Works a person who possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.
11. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the operations and maintenance activities required by this Approval.

## 7. MONITORING AND RECORDING

The Owner shall, upon commencement of operation of the Works, carry out the following monitoring

program:

1. All samples and measurements taken for the purposes of this Approval are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
2. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Septic Tank Effluent Monitoring Table included in **Schedule C**.
3. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Treated Effluent Monitoring Table included in **Schedule C**.
4. The Owner shall employ measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal system (except gravity systems), including but not limited to water/wastewater flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal system.
5. The Owner shall ensure that the sewage flow discharged into the Restaurant Infiltrator ATL System does not exceed **11,000 litres per day** and that discharged into the Beige House Infiltrator ATL System does not exceed **1,600 litres per day**.
6. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
  - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended from time to time by more recently published editions;
  - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" (January 1999), ISBN 0-7778-1880-9, as amended from time to time by more recently published editions; and
  - c. the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition), as amended from time to time by more recently published editions.
7. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

## 8. REPORTING

1. **One week** prior to the start up of the operation of the Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
2. The Owner shall report to the District Manager orally as soon as possible any non-compliance with the compliance limits, and in writing within **seven (7) days** of non-compliance.
3. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges), the Owner shall, within **fifteen (15) days** of the occurrence of any reportable spill as provided in Part X of the EPA and Ontario Regulation 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
4. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
5. The Owner shall prepare and submit a performance report, on an annual basis, within **ninety (90) days** following the end of each operational season to the District Manager. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
  - a. a summary and description of efforts made and results achieved (a summary and interpretation of all monitoring data) in meeting the Effluent Objectives of Condition 5 including an overview of the success and adequacy of the Works;
  - b. a review and assessment of performance of sewage Works, including all treatment units and disposal beds;
  - c. a description of any operating problems encountered and corrective actions taken at all sewage Works located at the property;
  - d. a record of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of all Works located at the property including but not limited to: records of maintenance inspections for the treatment system, records of septic tank effluent filters cleaning, records of septic tank pump-outs, records of sludge pump-outs accumulated from the treatment system, records of visual inspections of all disposal systems;
  - e. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
  - f. a summary and interpretation of all daily flow data and results achieved in not exceeding the

- maximum daily sewage flow discharged into each one of the subsurface disposal system;
- g. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
  - h. a summary of all spill or abnormal discharge events;
  - i. any other information the District Manager requires from time to time;

## **9. DECOMMISSIONING OF UN-USED SEWAGE WORKS**

1. The Owner shall properly abandon any portion of unused existing sewage Works, as directed below, and upon completion of decommissioning report in writing to the District Manager.
  - a. any sewage pipes leading from building structures to unused sewage Works components shall be disconnected and capped;
  - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
  - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes.

*The reasons for the imposition of these terms and conditions are as follows:*

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.

2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
4. Condition 4 is included to ensure that the works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
5. Condition 5 is imposed to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
6. Condition 6 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected. As well, the inclusion of an operations manual, maintenance agreement with the manufacturer for the treatment process/technology and a complete set of "as constructed" drawings governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the Ministry. Such information is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the work.
7. Condition 7 is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives specified in the Approval and that the Works does not cause any impairment to the receiving environment.
8. Condition 8 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.
9. Condition 9 is included to ensure that any components of un-used Works are properly decommissioned.

## **Schedule A**

1. Application for Environmental Compliance Approval submitted by Brad Smith, President of AON Inc., dated January 27, 2022 and received on February 18, 2022, for the proposed and existing subsurface disposal sewage Works, including the application report, final plans and specifications.

## Schedule B

### Effluent Objectives Table

<b>Final Effluent Parameter</b> (treated effluent from the Infiltrator ATL System)	<b>Concentration Objective</b> (milligrams per litre unless otherwise indicated)
Column 1	Column 2
CBOD <sub>5</sub>	20
Total Suspended Solids	20

## Schedule C

### Septic Tank Effluent Monitoring

<b>Sampling Location</b>	Balancing Tank of the Restaurant Sewage System
<b>Frequency</b>	Quarterly for the first three (3) years upon commencement of the operation of the System, and thereafter, once during every 12 month period, at least 10 months and not more than 18 months after previous sampling
<b>Sample Type</b>	Grab
<b>Parameters</b>	BOD <sub>5</sub> Total Suspended Solids (TSS)

### Treated Effluent Monitoring

<b>Sampling Location</b>	Infiltrator ATL System sampling port for the Restaurant Sewage System
<b>Frequency</b>	Quarterly for the first three (3) years upon commencement of the operation of the System, and thereafter, once during every 12 month period, at least 10 months and not more than 18 months after previous sampling
<b>Sample Type</b>	Grab
<b>Parameters</b>	CBOD <sub>5</sub> Total Suspended Solids (TSS)

<b>Sampling Location</b>	Infiltrator ATL System sampling port for the Beige House Sewage System
<b>Frequency</b>	Once during the first 12 months upon commencement of the operation of the System, and thereafter, once during every 12 month period, at least 10 months and not more than 18 months after previous sampling
<b>Sample Type</b>	Grab
<b>Parameters</b>	CBOD <sub>5</sub> Total Suspended Solids (TSS)



In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar\*  
Ontario Land Tribunal  
655 Bay Street, Suite 1500  
Toronto, Ontario  
M5G 1E5  
OLT.Registrar@ontario.ca

and

The Minister of the Environment,  
Conservation and Parks  
777 Bay Street, 5th Floor  
Toronto, Ontario  
M7A 2J3

and


The Director appointed for the purposes of  
Part II.1 of the *Environmental Protection Act*  
Ministry of the Environment,  
Conservation and Parks  
135 St. Clair Avenue West, 1st Floor  
Toronto, Ontario  
M4V 1P5

\* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or [www.olt.gov.on.ca](http://www.olt.gov.on.ca)

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 21st day of April, 2022



---

Fariha Pannu, P.Eng.  
Director  
appointed for the purposes of Part II.1 of the  
*Environmental Protection Act*

SW/

c: District Manager, MECP Peterborough District Office  
Jeremy Tracey, P.Eng. and Kevin Warner, Cambium Peterborough