

Ministry of the Environment, Conservation and Parks Ministère de l'Environnement, de la Protection de la nature et des Parcs

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 6607-C9RLDD Issue Date: April 25, 2022

1945054 Ontario Inc. 7299 Black Walnut Trail Mississauga, Ontario

L5N 7M4

Site Location: 14010 Hurontario St

Town of Caledon, Regional Municipality of Peel

L7C 2C1

You have applied under section 20.2 of Part II.1 of the <u>Environmental Protection Act</u>, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the establishment of sewage Works for the treatment and subsurface disposal of domestic sewage, with maximum daily sanitary sewage flow of 14,525 litres, rated for balanced flow of 7,500 litres per day to service a building consisting of one (1) restaurant, one (1) gas station and store, and one (1) sales office located at the above site location, consisting of the following:

Existing Works

Settling Tanks

two (2) interconnected settling tanks with combined capacity of 22,370 L, equipped with a Polylok effluent filter, two (2) access risers to grade, receiving sewage from the building and discharging to the existing pump chamber described below;

Pump Chamber

one (1) 6,800 L pump chamber, consisting of one (1) simplex submersible pump rated for 2.0 L/s at a total dynamic head (TDH) of 6.6 m, equipped with two (2) access risers to grade, a high level alarm and floats, discharging to the balancing tank described below;

Proposed Works

Balancing Tank

one (1) 9,000 L single compartment concrete balancing tank, equipped with a high level alarm and floats, two (2) access risers to grade, and duplex sewage handling pumps rated at 1.75 L/s at 1.7 m of TDH, discharging to the anaerobic digester described below;

Anaerobic Digester

one (1) 18,000 L capacity Waterloo Biofilter anaerobic digester equipped with an innertube with volume of 1,500 L, rated for a peak wastewater flow of 7,500 L/day, equipped with two (2) access risers to grade, an effluent filter on the outlet, discharging by gravity to the pump tank described below:

Pump Tank

one (1) 6,800 L capacity pump tank equipped two (2) access risers to grade, two (2) Little Giant WS50M-12-20 submersible effluent pumps rated for 94.6 L/min at at 10.4 m of TDH, operating on an alternating basis to discharge to the Waterloo Biofilter basket tank described below;

Waterloo Biofilter Basket Tank

one (1) 36,000 L capacity Waterloo Biofilter basket tank equipped with three (3) basket filters each filled with 8.6 m³ of foam Biofilter media, equipped with two (2) access risers to grade, a high level alarm and floats, two (2) submersible effluent pumps operating on separate timers, two (2) submersible pumps operating on an alternating timer, and a small low voltage air fan to promote aerobic conditions, split discharge back to the Anaerobic digester described above and the Waterloo Biofilter WaterNox-LS described below;

Waterloo Biofilter WaterNOx-LS Tank

one (1) 9,000 L capacity Waterloo Biofilter WaterNox-LS, equipped with two (2) access risers to grade, discharging by gravity to the Waterloo Biofilter polishing tank described below;

Waterloo Biofilter Polishing Basket Tank

one (1) 11,250 L capacity Waterloo Biofilter polishing basket tank equipped with two (2) baskets each filled with 4.1 m³ of foam media, two (2) access risers to grade, a high level alarm and floats, two (2) submersible effluent pumps operating on separate timers, two (2) submersible effluent pumps operating on alternating demand, and discharging at a rate of 3.5 L/s at 7.0 m of TDH to the Waterloo Biofilter WaterBOX-LS Tank and Type A dispersal bed described below;

Waterloo Biofilter WaterNOx-LS Tank (Closed Loop)

one (1) 9,000 L capacity Waterloo Biofilter WaterBox-LS Tank (Closed Loop), equipped with two (2) access risers to grade, collecting up to a maximum 6,000 L/day from the polishing tank described above, discharging to the bottom of the Waterloo Biofilter WaterNOx-LS tank and drained by gravity back to the Waterloo Biofilter polishing basket tank;

Type A Dispersal Bed

one (1) Type A dispersal bed consisting of eight (8) runs of 18.3 m length and 100 mm diameter distribution equally spaced 1.0 m apart and installed within a 300 mm thick stone layer with area of 160 m², having a minimum separation distance of 600 mm between the bottom of the stone layer and high groundwater table, rock or soil with a percolation rate (T) greater than 50 min/cm, a total area of contact (the total dispersal bed and mantle area) of 970 m² including a 600 mm deep sand layer consisting of imported soil with percolation rate of 6-10 min/cm, extending 23.9 m beyond the centrelines of the distribution piping in the direction water will flow, all in accordance with OBC requirements;

all other controls, electrical equipment, instrumentation, piping, pumps, valves and appurtenances essential for the proper operation of the aforementioned sewage works;

For the purpose of this environmental compliance approval, the following definitions apply:

- 1. "Approval" means this entire Approval document and any Schedules to it, including the application and Supporting Documentation;
- 2. "BOD₅" (also known as TBOD₅) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;
- 3. "CBOD₅" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
- 4. "Director" means a person appointed by the Minister pursuant to Section 5 of the EPA for the purposes of Part II.I of the EPA;
- 5. "Grab Sample" means an individual sample of at least 1000 millilitres collected in an appropriate container at a randomly selected time over a period of time not exceeding 15 minutes;
- 6. "District Manager" means the District Manager of the Halton-Peel;

- 7. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
- 8. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
- 9. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act,* R.S.O. 1990, c. P.28;
- 10. "Licensed Installer" means a person who is registered under the OBC to construct, install, repair, service, clean or empty on-site sewage systems;
- 11. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
- 12. "OBC" means the Ontario Building Code, Ontario Regulation 332/12 (Building Code) as amended to January 1, 2015, made under the *Building Code Act*, 1992, S.O. 1992, c. 23;
- 13. "Owner" means 1945054 Ontario Inc. and its successors and assignees;
- 14. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40, as amended;
- 15. "Rated Capacity" means design daily sanitary sewage flow for which the Works are approved to handle:
- 16. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
- 17. "Supporting Documentation" means the documents listed in Schedule A of this Approval;
- 18. "Works" means the approved sewage works, and includes Proposed Works, and Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.

- 2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
- 3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

2. EXPIRY OF APPROVAL

1. This Approval will cease to apply to those parts of the Works which have not been constructed within **five (5) years** of the date of this Approval.

3. CHANGE OF OWNER

- 1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
 - a. change of address of Owner;
 - b. change of Owner, including address of new owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act*, R.S.O. 1990, c.B17 shall be included in the notification to the District Manager;
 - d. change of name of the corporation where the Owner is or at any time becomes a corporation, and a copy of the most current information filed under the *Corporations Informations Act*, R.S.O. 1990, c. C39 shall be included in the notification to the District Manager;
- 2. In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.

4. CONSTRUCTION

- 1. The Owner shall ensure that the construction of the Works is supervised by a Licensed Installer or a Licensed Engineering Practitioner.
- 2. The Owner shall ensure that the Waterloo Biofilter Treatment system is installed in accordance with the Manufacturer's Installation Manual.
- 3. Upon construction of the Works, the Owner shall prepare a statement, certified by a Licensed Installer or a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.

4. Upon construction of the Works, the Owner shall prepare a set of as-built drawings showing the works "as constructed". "As-built" drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the site for the operational life of the Works and shall be made available for inspection by Ministry staff.

5. MONITORING AND RECORDING

The Owner shall, upon commencement of operation of the Works, carry out the following monitoring program:

- 1. All samples and measurements taken for the purposes of this Approval are to be taken at a time and in a location characteristic of the quality and quantity of the effluent stream over the time period being monitored.
- 2. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Influent Monitoring Table included in **Schedule B**.
- 3. Samples shall be collected at the sampling point(s), at the sampling frequencies and using the sample type specified for each parameter listed in the Effluent Monitoring Table included in **Schedule B**.
- 4. The Owner shall employ measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal system, including but not limited to water/wastewater flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal system.
- 5. The Owner shall ensure that flow of treated effluent discharged into the subsurface sewage system does not exceed 7,500 L/d.
- 6. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
 - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended from time to time by more recently published editions;
 - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" (January 1999), ISBN 0-7778-1880-9, as amended from time to time by more recently published editions; and
 - c. the publication "Standard Methods for the Examination of Water and Wastewater" (21st edition), as amended from time to time by more recently published editions.

7. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

6. EFFLUENT OBJECTIVES

- 1. The Owner shall design and undertake everything practicable to operate the Works in accordance with the following objectives:
 - a. Final Effluent parameters design objectives listed in the table(s) included in Schedule B.
- 2. For the purposes of subsection (1):
 - a. The concentration of Total Nitrogen named in Column 1 of Effluent Objectives Table listed in **Schedule B**, as measured at each monitoring event, should be compared to the corresponding concentration set out in Column 2 of Effluent Objectives Table listed in **Schedule B** and the corresponding concentration of Total Nitrogen should be met 10 months over any 12 month period.
 - b. The Owner shall use best efforts to maintain the pH of the effluent from the Works within the range of 6.5-8.5, at all times;

7. EFFLUENT LIMITS

- 1. The Owner shall design, construct, operate and maintain the Works such that the concentrations of the materials named as effluent parameters in the Effluent Limits Table in **Schedule B** are not exceeded in the effluent from the Works:
- 2. For the purposes of determining compliance with and enforcing subsection (1):
 - a. The monthly average concentration of CBOD₅ & TSS named in Column 1 of Effluent Limits Table listed in **Schedule B** shall not exceed the corresponding maximum concentration set out in Column 2 of Effluent Limits Table listed in **Schedule B**.
 - b. The concentration of Total Nitrogen named in Column 1 of Effluent Limits Table listed in **Schedule B**, as measured at each monitoring event, shall not exceed the corresponding maximum concentration set out in Column 2 of Effluent Limits Table listed in **Schedule B**.

8. OPERATIONS AND MAINTENANCE

- 1. The Owner shall ensure that, at all times, the Works and the related equipment and appurtenances used to achieve compliance with this Approval are properly operated and maintained.
- 2. The Owner shall prepare an operations manual within **six (6) months** of the introduction of sewage to the Works, that includes, but not necessarily limited to, the following information:

- a. operating procedures for routine operation of all the Works;
- b. inspection programs, including frequency of inspection, for all the Works and the methods or tests employed to detect when maintenance is necessary;
- c. repair and maintenance programs, including the frequency of repair and maintenance for all the Works; copies of maintenance contracts for any routine inspections & pump-outs should be included for all the tanks and treatment units;
- d. procedures for the inspection and calibration of monitoring equipment;
- e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the Spills Action Centre (SAC) and District Manager; and
- f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
- 3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
- 4. The Owner shall, upon the construction, prepare and make available for inspection by Ministry staff, a maintenance agreement with the manufacturer for the treatment process/technology. The maintenance agreement must be retained at the site and kept current for the operational life of the Works.
- 5. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
- 6. The Owner shall ensure that grass-cutting is maintained regularly over the subsurface disposal bed, and that adequate steps are taken to ensure that the area of the underground works is protected from vehicle traffic.
- 7. The Owner shall visually inspect the general area where sewage works are located for break-out once every month during the operating season.
- 8. In the event a break-out is observed from a subsurface disposal bed, the Owner shall do the following:
 - a. sewage discharge to that subsurface disposal system shall be discontinued;
 - b. the incident shall be **immediately** reported verbally to the Spills Action Centre (SAC) at

(416) 325-3000 or 1-800-268-6060;

- c. submit a written report to the District Manager within one (1) week of the break-out;
- d. access to the break-out area shall be restricted until remedial actions are complete;
- e. during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to the environment; and
- f. sewage generated at the site shall be safely collected and disposed of through a licensed waste hauler to an approved sewage disposal site.

9. REPORTING

- 1. One week prior to the start up of the operation of the Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
- 2. The Owner shall report to the District Manager orally as soon as possible any non-compliance with the compliance limits, and in writing within seven (7) days of non-compliance.
- 3. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges), the Owner shall, within **fifteen (15) days** of the occurrence of any reportable spill as provided in Part X of the EPA and Ontario Regulation 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
- 4. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
- 5. The Owner shall prepare and submit a performance report, on an annual basis to the District Manager. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:
 - a. a summary and description of efforts made and results achieved in meeting the Effluent Objectives of (Condition 6);
 - b. a summary and interpretation of all monitoring data and a comparison to the Effluent Limits (Condition 7) including an overview of the success and adequacy of the Works, and a Contingency Plan in the event of not in compliance with the Effluent Limits.
 - c. a review and assessment of performance of sewage works, including all treatment units and disposal beds;

- d. a description of any operating problems encountered and corrective actions taken at all sewage Works located at the property;
- e. a record of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of all Works located at the property' including but not limited to: records of maintenance inspections for the treatment system, records of septic tank effluent filters cleaning, records of septic tank pump-outs, records of sludge pump-outs accumulated from the treatment system, records of visual inspections of all disposal systems;
- f. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
- g. a summary and interpretation of all daily flow data and results achieved in not exceeding the maximum daily sewage flow discharged into each one of the subsurface disposal system;
- h. a summary of any complaints received during the reporting period and any steps taken to address the complaints;
- i. a summary of all spill or abnormal discharge events;
- j. any other information the District Manager requires from time to time;

10. DECOMMISSIONING OF UN-USED SEWAGE WORKS

- 1. The Owner shall properly abandon any portion of unused existing sewage Works, as directed below, and upon completion of decommissioning report in writing to the District Manager.
 - a. any sewage pipes leading from building structures to unused sewage Works components shall be disconnected and capped;
 - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
 - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes;

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the

precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.

- 2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
- 3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
- 4. Condition 4 is included to ensure that the works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
- 5. Condition 5 is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives specified in the Approval and that the Works does not cause any impairment to the receiving watercourse.
- 6. Condition 6 is imposed to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
- 7. Condition 7 is imposed to ensure that the effluent discharged from the Works to the subsurface meets the Ministry's effluent quality requirements thus minimizing environmental impact on the receiver.
- 8. Condition 8 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected. As well, the inclusion of an operations manual, maintenance agreement with the manufacturer for the treatment process/technology and a complete set of "as constructed" drawings governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the owner and made available to the Ministry. Such information is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the work.
- 9. Condition 9 is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for all the terms and conditions outlined in this Approval, so that the Ministry can work with the Owner in resolving any problems in a timely manner.
- 10. Condition 10 is included to ensure that any components of un-used Works are properly decommissioned.

Schodulo A

| | Schedule A |
|----|---|
| 1. | Application for Environmental Compliance Approval dated June 16, 2021 and received on July 23 2021. |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Schedule B

Influent Monitoring Table

| Sampling Location | upstream of the Treatment System |
|-------------------|----------------------------------|
| Frequency | Monthly |
| Sample Type | Grab |
| Parameters | BOD5 |
| | Total Suspended Solids (TSS) |
| | Total Kjeldahl Nitrogen (TKN) |

Effluent Monitoring Table

Sampling Location: on discharge from the final Treatment System upstream from subsurface disposal bed

| Effluent Parameter | Frequency | Sample Type |
|--------------------------|---------------------------|----------------|
| CBOD ₅ | Bi-weekly (twice a month) | Grab |
| Total Suspended Solids | Bi-weekly (twice a month) | Grab |
| Total Nitrogen | Monthly | Grab |
| Total Inorganic Nitrogen | Monthly | Grab |
| Nitrate-Nitrogen | Monthly | Grab |
| Ammonium Nitrogen | Monthly | Grab |
| Гotal Kjedhal Nitrogen | Monthly | Grab |
| рН | Monthly | Grab |

Effluent Objectives Table

| Effluent Parameter | Concentration Objective |
|---|---|
| (tested on discharge from the final Treatment | (milligrams per litre unless otherwise indicated) |
| System upstream from subsurface disposal | |
| bed) | |
| Total Nitrogen | 5.5 |
| рН | 6.5-8.5 (inclusive) |

Effluent Limits Table

| Effluent Parameter (tested on outlet from the final Waterloo Biofilter Treatment Units) | Concentration Limit (milligrams per litre unless otherwise indicated) |
|---|---|
| CBOD5 | 10 |
| Total Suspended Solids (TSS) | 10 |
| Total Nitrogen | 10 |

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

- 1. The name of the appellant;
- 2. The address of the appellant;
- 3. The environmental compliance approval number;
- 4. The date of the environmental compliance approval;
- 5. The name of the Director, and;
- 6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

and

This Notice must be served upon:

Registrar*
Ontario Land Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5
OLT.Registrar@ontario.ca


The Minister of the Environment, Conservation and Parks 777 Bay Street, 5th Floor and Toronto, Ontario M7A 2J3 The Director appointed for the purposes of Part II.1 of the *Environmental Protection Act* Ministry of the Environment, Conservation and Parks 135 St. Clair Avenue West, 1st Floor Toronto, Ontario M4V 1P5

* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at https://ero.ontario.ca/, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 25th day of April, 2022



Fariha Pannu, P.Eng.
Director
appointed for the purposes of Part II.1 of the
Environmental Protection Act

ZM/

c: District Manager, MECP Halton-Peel District Katherine Rentsch, C.F. Crozier and Associates Inc.