

**ENVIRONMENTAL COMPLIANCE APPROVAL**

NUMBER 8172-CN5SUP  
Issue Date: January 30, 2023

The Congregation of the Resurrection in Ontario  
265 Westmount Rd N  
Waterloo, Ontario  
N2L 3G7

Site Location: Private Cottage Lot 913, Conestogo Lake  
Lot 15, Concession 3  
Mapleton Township,  
County of Wellington  
N0G 1P0

*You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:*

establishment, use and operation of the Proposed Works for the treatment of sanitary sewage and subsurface disposal of treated effluent, rated at 1,100 litres per day to service a proposed two (2) bedroom dwelling for recreational use, located at the above noted location, and consisting of the following:

**Proposed Works:**

***Anaerobic Digester with Internal Pump Chamber***

- one (1) 4,950 litre anaerobic digester (septic tank) complete with an internal pump chamber, with a cover up to ground level, equipped with a high level audible/visual alarm system, an inline filter and one (1) submersible effluent pump time-dosing to a Waterloo Biofilter treatment unit as described below.

***Waterloo Biofilter***

- one (1) precast concrete tank containing two (2) Waterloo Biofilter mesh basket Biofilter units filled with a minimum foam volume of 2.2 cubic-metres, equipped with one (1) single dispersal pump providing a minimum pressure head of 600 millimetres at the furthest point in the distribution system, time-dosing treated effluent to a proposed shallow buried trench disposal bed, and recirculating effluent to the inlet of the digester for additional treatment.

### ***Shallow Buried Trench Disposal Bed***

- one (1) shallow buried trench disposal bed, consisting of three (3) runs of eleven (11) metre long pipe (total of 33 metres), each trench consisting of a minimum 25 millimetre diameter pressure distribution pipe with orifices of minimum 3 millimetre diameter in size spaced equally along the length of the pipe, with each trench spaced 2 metres apart, all constructed in imported sand fill (T = 6-10 minutes/centimetre) placed below the existing ground level, and providing a minimum of 300 millimetre layer below bottoms of trenches.

#### **Existing Works :**

- Decommissioning of the existing septic tank and leaching bed.

all in accordance with the supporting documentation submitted to the Ministry as listed in the **Schedule A** in this Approval.

*For the purpose of this environmental compliance approval, the following definitions apply:*

#### **Definitions:**

1. "Approval" means this entire document and any schedules attached to it, and the application;
2. "BOD<sub>5</sub>" (also known as TBOD<sub>5</sub>) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demand;
3. "CBOD<sub>5</sub>" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
4. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
5. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c.E.19, as amended;
6. "Licensed Installer" means a person who is registered under the Building Code to construct, install, repair, service, clean or empty on-site sewage systems;
7. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
8. "OBC" means the Ontario Building Code, Ontario Regulation 332/12 (Building Code) as amended to January 1, 2015, made under the *Building Code Act*, 1992, S.O. 1992, c. 23;
9. "Owner" means The Congregation of the Resurrection in Ontario, and includes their successors and

assignees;

10. "OWRA" means the *Ontario Water Resources Act* , R.S.O. 1990, c.O40, as amended;
11. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
12. "Works" means the sewage works described in the Owner's application, and this Approval, and includes both Proposed Works and Existing Works previously constructed.

*You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:*

## **TERMS AND CONDITIONS**

### **1. GENERAL PROVISIONS**

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

### **2. EXPIRY OF APPROVAL**

1. This Approval will cease to apply to those parts of the Proposed Works which have not been constructed within **five (5) years** of the issuance date of this Approval.

### **3. CHANGE OF OWNER**

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
  - a. change of address of Owner;
  - b. change of Owner, including address of new owner;
  - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act* , R.S.O. 1990, c.B17 shall be

included in the notification;

d. change of name of the corporation and a copy of the most current information filed under the *Corporations Information Act*, R.S.O. 1990, c. C39 shall be included in the notification.

2. In the event of any change in ownership of the Works, other than a change to a successor municipality, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
3. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

#### **4. CONSTRUCTION**

1. The Owner shall ensure that the construction of the Works is supervised by a Licensed Installer.
2. The Owner shall ensure that the Works are constructed such that minimum horizontal clearance distances as specified in the OBC are satisfied.
3. Upon construction of the Works, the Owner shall prepare a statement, certified by a Licensed Installer that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff and staff of the local municipality.
4. Upon construction of the Works, as-built drawing(s) showing the Works “as constructed” shall be prepared by the Licensed Installer. The drawing(s) shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the Works for the operational life of the Works.

#### **5. OPERATIONS, MAINTENANCE, MONITORING AND RECORDING**

1. The Owner shall ensure that at all times, the Works and related equipment and appurtenances which are installed or used to achieve compliance with this Approval are properly operated and maintained.
2. The Owner shall sign a Service and Maintenance Agreement with the manufacturer or approved agent of the Waterloo Biofilter treatment system. The maintenance agreement must be retained at the site for as long as the Works are in operation, kept current and made available for inspection by the Ministry staff.
3. The Owner shall receive from the manufacturer or distributor of Waterloo Biofilter printed literature that describes the unit in detail and provides complete instructions regarding the operation, servicing, and maintenance requirements of the unit and its related components necessary to ensure the continued proper operation in accordance with the original design and specifications.
4. The Owner shall ensure that the treatment system is at minimum inspected annually by the Waterloo

Biofilter authorized personnel, and maintained according to the manufacturer's recommendations including minimal yearly effluent sampling for CBOD<sub>5</sub> and Total Suspended Solids to ensure that it meets design objectives of 10 mg/l for both CBOD<sub>5</sub> and Total Suspended Solids in a grab effluent sample before discharge to the subsurface disposal bed;

5. The Owner shall ensure that the septic tank(s) is pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filter(s) is cleaned out at minimum once a year (or more often if required).
6. The Owner shall ensure that grass-cutting is maintained regularly over the subsurface disposal bed(s), and that adequate steps are taken to ensure that the area of the underground Works is protected from vehicle traffic.
7. The Owner shall visually inspect the general area where Works are located for break-out once every month during the operating season.
8. In the event a break-out is observed from a subsurface disposal bed, the Owner shall do the following:
  - a. sewage discharge to that subsurface disposal system shall be discontinued;
  - b. the incident shall be **immediately** reported verbally to the Spills Action Centre (SAC) at (416) 325-3000 or 1-800-268-6060;
  - c. submit a written report to the District Manager within **one (1) week** of the break-out;
  - d. access to the break-out area shall be restricted until remedial actions are complete;
  - e. during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to the environment; and
  - f. sewage generated at the site shall be safely collected and disposed of through a licensed waste hauler to an approved sewage disposal site.
9. The Owner shall maintain a logbook to record the results of Operation and Maintenance activities specified in the above subclauses, and shall keep the logbook at the site and make it available for inspection by the Ministry staff.
10. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

## 6. REPORTING

1. **One week** prior to the start up of the operation of the Works, the Owner shall notify the District

Manager (in writing) of the pending start up date of the Works.

2. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within **fifteen (15) days** of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.

## 7. DECOMMISSIONING OF UN-USED WORKS

1. The Owner shall properly abandon any portion of unused Existing Works, as directed below, and upon completion of decommissioning report in writing to the District Manager.
  - a. any sewage pipes leading from building structures to unused Works components shall be disconnected and capped;
  - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
  - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes;

*The reasons for the imposition of these terms and conditions are as follows:*

1. Condition 1 is imposed to ensure that the Works are built and operated in the manner in which they were described for review and upon which approval was granted. This condition is also included to emphasize the precedence of Conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. The condition also advises the Owners their responsibility to notify any person they authorized to carry out work pursuant to this Approval the existence of this Approval.
2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved Works and to ensure that subsequent owners of the Works are made aware of the Approval

and continue to operate the Works in compliance with it.

4. Condition 4 is included to ensure that the Works are constructed, and may be operated and maintained such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.
5. Condition 5 is included to require that the Works be properly operated, maintained, and equipped such that the environment is protected.
6. Condition 6 is included to ensure that the Ministry records are complete.
7. Condition 7 is included to ensure that any components of un-used Works are properly decommissioned.

## **Schedule A**

1. Application for Environmental Compliance Approval submitted by Marc Ethier of E2TECH Service on behalf of The Congregation of the Resurrection in Ontario, dated August 16, 2022 and received on September 21, 2022, for the proposed Waterloo Biofilter Treatment System and shallow buried trench, including design report, final plans and specifications.



In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar\*  
Ontario Land Tribunal  
655 Bay Street, Suite 1500  
Toronto, Ontario  
M5G 1E5  
OLT.Registrar@ontario.ca

and

The Minister of the Environment,  
Conservation and Parks  
777 Bay Street, 5th Floor  
Toronto, Ontario  
M7A 2J3

and


The Director appointed for the purposes of  
Part II.1 of the *Environmental Protection Act*  
Ministry of the Environment,  
Conservation and Parks  
135 St. Clair Avenue West, 1st Floor  
Toronto, Ontario  
M4V 1P5

\* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or [www.olt.gov.on.ca](http://www.olt.gov.on.ca)

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 30th day of January, 2023

A handwritten signature in black ink that reads "Fariha Pannu." The signature is written in a cursive style with a large, sweeping initial 'F'.

---

Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the  
*Environmental Protection Act*

ZD/

c: District Manager, MECP Guelph  
Marc Ethier, E2TECH Services