

Ministry of the Environment, Conservation and Parks Ministère de l'Environnement, de la Protection de la nature et des Parcs

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 0595-CRWNAZ Issue Date: June 6, 2023

Camp Kawartha Incorporated 1010 Birchview Road Douro-Dummer, Ontario K0L 2H0

Site Location: Camp Kawartha 1010 Birchview Road Township of Douro-Dummer County of Peterborough, Ontario

You have applied under section 20.2 of Part II.1 of the <u>Environmental Protection Act</u>, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the replacement, expansion, usage and operation of Works for the treatment of sanitary sewage from an outdoor education centre - Camp Kawartha, and subsurface disposal of treated effluent, rated at a total Maximum Daily Flow of 40,460 litres per day, and located at the above Site Location, consisting of the following:

Details of Service Area

- a central hub buildings including a dining hall and a shower/washroom building for accommodating a maximum of 250 persons
- a two-bedroom staff cabin and a nurse's cabin

Proposed Works

New sewage treatment and subsurface disposal system rate at Maximum Daily Flow of 37,500 litres, serving the central hub buildings including dining hall and shower/washroom building, consisting of the follow:

- one (1) 22,750 litre septic tank (existing), equipped with an effluent filter, discharging into a septic/sludge tank;
- two (2) 27,500 litre septic/sludge tanks (identified as Anaerobic Digesters), operating in series, each equipped with an effluent filter, discharging into a balancing/equalization pump tank;

one (1) 27,500 litre balancing/equalization pump tank, equipped with duplex pumps, discharging into three (3) Biofilter Tanks;

- three (3) 27,500 litre Waterloo Biofilter Tanks (Tank #1, Tank #2 and Tank #3), operation in parallel, each tank comprised of spray units, air fan assembly and two (2) mesh baskets filled with Biofilter media, equipped with a total of 65.4 cubic meters of Biofilter media, with treated effluent from Tanks #2 and #3 flow via gravity to Tank #1 (Waterloo Biofilter Effluent Pump Tank) that is equipped with a simplex pump to recirculate up to 50% of the treated effluent to the first Anaerobic Digester for denitrification and duplex effluent pumps dosing the remaining treated effluent to a Type A disposal bed with a dosing rate of 2,316 litres per dose;
- one (1) raised Type A Dispersal Bed configured as two cells, each cell having a total stone area of 377 square metres and consisting of a 300 millimetre thick stone layer and a 600 millimetre thick imported sand layer, with each stone layer protected with a permeable Geotextile fabric and includes 12 runs of 25.0 metre long 75 millimetre diameter distribution pipes, and with the imported sand layer having a percolation time of 6 to 10 minutes per centimetre, complete with a 2,063 square metre mantle area over the two cells and extending at least 15 metres beyond the last distribution pipe towards to northwest in the direction of groundwater flow with a minimum of 300 millimetre thick sand layer, covered by 150 millimetre thick topsoil; and
- including all other mechanical system, electrical system, instrumentation and control system, standby power system, piping, pumps, valves and appurtenances essential for the proper, safe and reliable operation of the Works in accordance with this Approval, in the context of process performance and general principles of wastewater engineering only.

Existing Works

٠

•

•

•

Septic System Serving the Two-bedroom Staff Cabin

• one (1) septic system rated at 1,640 litres per day, consisting of a 3,600 litre septic tank, and a filter bed comprised of three (3) parallel runs of 6.1 meter long and 75 mm diameter distribution pipes spaced at a centre-line distance of 1.2 metres, including an 18.3 square meter filter bed area.

Septic System Serving the Nurse's Station

• one (1) septic system rated at 1,320 litres per day, consisting of consisting of a 3,600 litre septic tank, and a filter bed comprised of four (4) parallel runs of 4.9 meter long and 75 mm diameter distribution pipes spaced at a centre-line distance of 0.9 metre, including an 18.3 square meter filter bed area.

All in accordance with the submitted supporting documents listed in Schedule A.

For the purpose of this environmental compliance approval, the following definitions apply:

- 1. "Approval" means this entire Approval document and any Schedules to it, including the application and Supporting Documentation;
- 2. "CBOD5" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
- 3. "Commissioned" means the construction is complete and the system has been tested, inspected, and is ready for operation consistent with the design intent;
- 4. "Director" means a person appointed by the Minister pursuant to Section 5 of the EPA for the purposes of Part II.I of the EPA;
- 5. "District Manager" means the District Manager of the Peterborough District Office;
- 6. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
- 7. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
- 8. "Grab Sample" means an individual sample of at least 1000 millilitres collected in an appropriate container at a randomly selected time over a period of time not exceeding 15 minutes;
- 9. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act,* R.S.O. 1990, c. P.28;
- 10. "Maximum Daily Flow" means the largest volume of flow to be received during a one-day period for which the Works is designed to handle;
- 11. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
- 12. "OBC" means the Ontario Building Code, Ontario Regulation 332/12 (Building Code) as amended to January 1, 2015, made under the *Building Code Act*, 1992, S.O. 1992, c. 23;
- 13. "Operating Agency" means the Owner, or the person or entity that is authorized by the Owner for the management, operation, maintenance, or alteration of the Works in accordance with this Approval;
- 14. "Owner" means Camp Kawartha Incorporated and its successors and assignees;
- 15. "OWRA" means the Ontario Water Resources Act, R.S.O. 1990, c. O.40, as amended;

- 16. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
- 17. "Single Sample Result" means the test result of a parameter in the effluent discharged on any day, as measured by a probe, analyzer or in a composite or grab sample, as required; and
- 18. "Works" means the approved sewage works, and includes Proposed Works, and Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

- 1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
- 2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
- 3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

2. CHANGE OF OWNER AND OPERATING AGENCY

- 1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within thirty (30) days of the change occurring:
 - a. change of address of Owner;
 - b. change of Owner, including address of new owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act, R.S.O. 1990, c. B.17* shall be included in the notification;
 - d. change of name of the corporation and a copy of the most current information filed under the *Corporations Information Act, R.S.O. 1990, c. C.39* shall be included in the notification.
- 2. The Owner shall notify the District Manager, in writing, of any of the following changes within thirty (30) days of the change occurring:

- a. change of address of the Operating Agency;
- b. change of the Operating Agency, including address of the new Operating Agency.
- 3. In the event of any change in ownership of the Works, the Owner shall notify the succeeding owner in writing, of the existence of this Approval, and forward a copy of the notice to the District Manager.
- 4. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

3. CONSTRUCTION OF PROPOSED WORKS

- 1. All Proposed Works in this Approval shall be constructed and installed and must commence operation within five (5) years of issuance of this Approval, after which time the Approval ceases to apply in respect of any portions of the Works not in operation. In the event that the construction, installation and/or operation of any portion of the Proposed Works is anticipated to be delayed beyond the time period stipulated, the Owner shall submit to the Director an application to amend the Approval to extend this time period, at least six (6) months prior to the end of the period. The amendment application shall include the reason(s) for the delay and whether there is any design change(s).
- 2. The Owner shall ensure that the construction of the Works is supervised by a Licensed Engineering Practitioner.
- 3. The Owner shall ensure that the Works are constructed such that minimum horizontal clearance distances as specified in the OBC are satisfied.
- 4. The Owner shall ensure that the Waterloo Biofilter treatment system is installed in accordance with the manufacturer's installation manual.
- 5. The Owner shall ensure that an imported soil that is required for construction of any subsurface disposal bed as per this Approval is tested and verified by the Licensed Engineering Practitioner for the percolation time (T) prior to delivering to the site location and the written records are kept at the site. In addition, soil samples of native material and imported sand fill are to be tested for calcium, aluminium, and iron content to confirm phosphorus retaining ability.
- 6. Within **six (6) months** of the Works being Commissioned, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry staff.
- 7. Within **six (6) months** of the Works being Commissioned, the Owner shall prepare a set of as-built drawings showing the Works "as constructed". "As-built" drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the site for the operational life of the Works and shall be made available for inspection by Ministry staff.

4. DESIGN OBJECTIVES

- 1. The Owner shall design and undertake everything practicable to operate the Works in accordance with the following objectives:
 - a. The objective that the concentrations of the materials named as effluent parameters in the Effluent Objectives Table listed in **Schedule B** are not exceeded in the effluent from the Waterloo Biofilter Effluent Pump Tank, prior to discharging into the Type A dispersal Bed.
 - b. Treated effluent from the Waterloo Biofilter Effluent Pump Tank discharged into the Type A Dispersal Bed does not exceed the rated Maximum Daily Flow of 37,500 litres.

5. OPERATION AND MAINTENANCE

- 1. The Owner shall ensure that, at all times, the Works and the related equipment and appurtenances used to achieve compliance with this Approval are properly operated and maintained. Proper operation and maintenance shall include effective performance, adequate funding, adequate staffing and training, including training in all procedures and other requirements of this Approval and the OWRA and regulations, adequate laboratory facilities, process controls and alarms and the use of process chemicals and other substances used in the Works.
- 2. The Owner shall prepare an operations manual within **six (6) months** of the introduction of sewage to the Works, that includes, but not necessarily limited to, the following information:
 - a. operating procedures for routine operation of all the Works;
 - b. inspection programs, including frequency of inspection, for all the Works and the methods or tests employed to detect when maintenance is necessary;
 - c. repair and maintenance programs, including the frequency of repair and maintenance for all the Works; copies of maintenance contracts for any routine inspections & pump-outs should be included for all the tanks and treatment units;
 - d. procedures for the inspection and calibration of monitoring equipment;
 - e. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the Spills Action Centre (SAC) and District Manager; and
 - f. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
- 3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the

manual available to Ministry staff.

- 4. The Owner shall, upon the construction, prepare and make available for inspection by Ministry staff, a maintenance agreement with the manufacturer for the treatment process/technology or its authorized agent. The maintenance agreement must be retained at the site and kept current for the operational life of the Works.
- 5. The Owner shall ensure that all septic tanks are pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filters are cleaned out at minimum once a year or more often if required.
- 6. The Owner shall ensure that the oil/grease interceptor is inspected and maintained on regular basis as required, and grease is disposed off site by a licensed hauler (e.g. at approved recycling sites).
- 7. The Owner shall ensure that grass-cutting is maintained regularly over the subsurface disposal bed(s), and that adequate steps are taken to ensure that the area of the underground Works is protected from vehicle traffic.
- 8. The Owner shall visually inspect the general area where Works are located for break-out once every month during the operating season.
- 9. In the event a break-out is observed from a subsurface disposal bed, the Owner shall do the following:
 - a. sewage discharge to that subsurface disposal system shall be discontinued;
 - b. the incident shall be **immediately** reported verbally to the Spills Action Centre (SAC) at (416) 325-3000 or 1-800-268-6060;
 - c. submit a written report to the District Manager within **one (1) week** of the break-out;
 - d. access to the break-out area shall be restricted until remedial actions are complete;
 - e. during the time remedial actions are taking place the sewage generated at the site shall not be allowed to discharge to the environment; and
 - f. sewage generated at the site shall be safely collected and disposed of through a licensed waste hauler to an approved sewage disposal site.
- 10. The Owner shall employ for the overall operation of the Works a person who possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.
- 11. The Owner shall retain for a minimum of **five (5) years** from the date of their creation, all records and information related to or resulting from the operations and maintenance activities required by this Approval.

6. MONITORING AND RECORDING

- 1. The Owner shall, upon commencement of operation of the Works, carry out a scheduled monitoring program of collecting samples at the required sampling points, at the frequency specified or higher, by means of the specified sample type and analyzed for each parameter listed in the tables under the monitoring program included in **Schedule C** and record all results, as follows:
 - a. all samples and measurements are to be taken at a time and in a location characteristic of the quality and quantity of the sewage stream over the time period being monitored.
 - b. definitions and preparation requirements for each sample type are included in document referenced in Paragraph 2.b.
 - c. definitions for frequency:
 - i. Monthly means once every month
 - ii. Semi-annually means once every six months
- 2. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
 - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended;
 - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater Version 2.0" (January 2016), PIBS 2724e02, as amended;
 - c. the publication "Standard Methods for the Examination of Water and Wastewater", as amended; and
 - d. for any parameters not mentioned in the documents referenced in Paragraphs 3.a, 3.b and 3.c, the written approval of the District Manager shall be obtained prior to sampling.
- 3. The Owner shall employ measurement devices to accurately measure quantity of effluent being discharged to each individual subsurface disposal bed, including but not limited to water/wastewater flow meters, event counters, running time clocks, or electronically controlled dosing, and shall record the daily volume of effluent being discharged to the subsurface disposal bed.
- 4. The Owner shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

7. REPORTING

- 1. One week prior to the start up of the operation of the Proposed Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
- 2. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within fifteen (15) days of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
- 3. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
- 4. The Owner shall prepare and submit a performance report on an annual basis and submit to the District Manager in an electronic format within ninety (90) days following the end of each operational season. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period:
 - a. a summary and description of efforts made and results achieved in meeting the effluent objectives of (Condition 4);
 - b. a summary and interpretation of groundwater monitoring data monitoring data;
 - c. a review and assessment of the performance of the Works, including all treatment units and subsurface disposal beds;
 - d. a description of any operating problems encountered and corrective actions taken at all Works located at the property;
 - e. a record of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of all Works located at the property including but not limited to: records of maintenance inspections for the treatment system, records of septic tank effluent filters cleaning, records of septic tank pump-outs, records of sludge pump-outs accumulated from the treatment system, records of visual inspections of all disposal systems;
 - f. a summary of any effluent quality assurance or control measures undertaken in the reporting period;
 - g. a summary and interpretation of all daily flow data and results achieved in not exceeding the maximum daily sewage flow discharged into each one of the subsurface disposal system;
 - h. a summary of any complaints received during the reporting period and any steps taken to address the

complaints;

- i. a summary of all spill or abnormal discharge events; and
- j. any other information the District Manager requires from time to time.

8. DECOMMISSIONING OF UN-USED WORKS

- 1. The Owner shall properly abandon any portion of unused existing septic systems, as directed below, and upon completion of decommissioning report in writing to the District Manager:
 - a. any sewage pipes leading from building structures to unused septic system components shall be disconnected and capped;
 - b. any unused septic tanks, holding tanks and pump chambers shall be completely emptied of its content by a licensed hauler and either be removed, crushed and backfilled, or be filled with granular material;
 - c. if the area of the existing leaching bed is going to be used for the purposes of construction of a replacement bed or other structure, all distribution pipes and surrounding material must be removed by a licensed hauler and disposed off site at an approved waste disposal site; otherwise the existing leaching bed may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes.

Schedule A

1. Application for Environmental Compliance Approval dated April 4, 2023 and received on April 5, 2023, submitted by Camp Kawartha Incorporated, for the proposed replacement and expansion of sanitary sewage treatment and subsurface disposal system, including design brief, engineering drawings and specifications.

Schedule B

Effluent Objectives For the Effluent from the Waterloo Biofilter Treatment Unit

Effluent Parameter	Averaging Calculator	Objectives
		(maximum unless otherwise indicated)
CBOD5	Single Sample Result	10.0 mg/L*^{1}
Total Suspended Solids	Single Sample Result	10.0 mg/L

Note^{*1}: mg/L means milligrams per litre

Schedule C - Monitoring Program

Table C-1 Efficient Wonitoring Table (Fart 1)		
Sample location	The effluent from the Waterloo Biofilter Effluent Pump Tank, prior to	
	discharging into the Type A Dispersal Bed	
Frequency	Monthly (during operation)	
Sample Type	Grab	
Parameters	CBOD5, Total Suspended Solids	

Table C-1 Effluent Monitoring Table (Part 1)

Table C-2 Efficient Monitoring Table (Fart 2)"		
Sample location	1. Influent to be collected from the existing 22,750 litre septic tank	
	2. The effluent from the Waterloo Biofilter Effluent Pump Tank, prior to	
	discharging into the Type A Dispersal Bed	
Frequency	Semi-annually (summer and late fall)	
Sample Type	Grab	
Parameters	CBOD5, BOD, Total Suspended Solids, pH, Alkalinity, Total Dissolved	
	Solids, Phosphorus (total), Total Kjeldahl Nitrogen, Ammonia and	
	Ammonium Nitrogen, Nitrate Nitrogen, Nitrate Nitrogen, Organic Nitrogen,	
	Phosphorus (dissolved), Unionized Ammonia	

Table C-2 Effluent Monitoring Table (Part 2)*

Note *: The monitoring program specified in this Table C-2 may, after three (3) years of monitoring in accordance with this program, be stopped or modified by the District Manager in writing.

Table C-5 Groundwater Monitoring Table		
Sample location	There (3) groundwater monitoring wells:	
	1. MW101-19	
	2. MW102-19	
	3. MW103-19	
Frequency	Semi-annually (summer and late fall)	
Sample Type	Grab	
Parameters	Groundwater level, pH (field), Temperature (field), Conductivity (Field),	
	CBOD, BOD, Total Suspended Solids, pH, Alkalinity, Total Dissolved	
	Solids, Total Kjeldahl Nitrogen, Ammonia and Ammonium Nitrogen, Nitrate	
	Nitrogen, Nitrate Nitrogen, Organic Nitrogen, Phosphorus (total),	
	Phosphorus (dissolved), Unionized Ammonia	

Table C-3 Groundwater Monitoring Table*

Note *: The monitoring program specified in this Table C-3 may, after three (3) years of monitoring in accordance with this program, be stopped or modified by the District Manager in writing.

The reasons for the imposition of these terms and conditions are as follows:

- 1. Condition 1 regarding general provisions is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted.
- 2. Condition 2 regarding change of Owner and Operating Agency is included to ensure that the Ministry records are kept accurate and current with respect to ownership and Operating Agency of the Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
- 3. Condition 3 regarding construction of Proposed Works/record drawings is included to ensure that the Works are constructed in a timely manner so that standards applicable at the time of Approval of the Works are still applicable at the time of construction to ensure the ongoing protection of the environment, and that prior to the commencement of construction of the portion of the Works that are approved in principle only, the Director will have the opportunity to review detailed design drawings, specifications and an engineer's report containing detailed design calculations for that portion of the Works, to determine capability to comply with the Ministry's requirements stipulated in the terms and conditions of the Approval, and also ensure that the Works are constructed in accordance with the Approval and that record drawings of the Works "as constructed" are updated and maintained for future references.
- 4. Condition 4 regarding design objectives is imposed to establish non-enforceable design objectives to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
- 5. Condition 5 regarding operation and maintenance is included to require that the Works be properly operated, maintained, funded, staffed and equipped such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented. As well, the inclusion of a comprehensive operations manual governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the Owner. Such a manual is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the Works.
- 6. Condition 6 regarding monitoring and recording is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives and compliance limits.
- 7. Condition 7 regarding reporting is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for this Approval.

8. Condition 8 regarding decommissioning of un-used works is included to ensure that any components of un-used septic systems are properly decommissioned.

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

- 1. The name of the appellant;
- 2. The address of the appellant;
- 3. The environmental compliance approval number;
- 4. The date of the environmental compliance approval;
- 5. The name of the Director, and;
- 6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at https://ero.ontario.ca/, you can determine when the leave to appeal period ends.

The Director appointed for the nurposes of

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 6th day of June, 2023

Fariha Parnu.

Fariha Pannu, P.Eng. Director appointed for the purposes of Part II.1 of the *Environmental Protection Act*

NH/

c: District Manager, MECP Peterborough District Office Jeremy Tracey, P.Eng., Cambium Inc.