

ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 4266-CWNFTY
 Issue Date: December 7, 2023

JPI Farms Inc.
 422 Mersea Road 7
 Leamington, Ontario
 N8H 3V8

Site Location: 422 Mersea Road 7
 Municipality of Leamington
 County of Essex, Ontario

You have applied under section 20.2 of Part II.1 of the Environmental Protection Act, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

establishment, expansion, usage and operation of Works, for the treatment of **sanitary** sewage from existing and new bunkhouses, and washroom facilities serving greenhouse, warehouse and office buildings and disposal of Final Effluent to a municipal drain - Silver Creek Drain via a new Phases 1 to 4 swage treatment system, existing Phased 1 and 2 sewage treatment systems and Final Effluent disposal facilities, as follows:

Service Area

- new Phases 3 and 4 greenhouse development for accommodating a total of 192 persons residing on-site, up to 52 persons residing off-site, 12 loading docks and a 3-bedroom residence
- existing Phases 1 and 2 greenhouse development for accommodating a total of 70 persons residing on-site, up to 19 persons residing off-site, one accessory residence and 5 loading docks

Maximum Daily Flow of the Sanitary Sewage Treatment Systems

| | |
|---------------------------|---|
| | Upon Completion of Construction of all Proposed Works |
| Maximum Daily Flow | 75,000 litre per day (0.87 litre per second) |

PROPOSED WORKS - Phases 1 to 4 Sewage Treatment and Surface Water Discharge System

Sewage Treatment and Surface Water Discharge Systems, having a Maximum Daily Flow of 75,000 litres per day and a design average daily flow of 60,000 litres per day further treatment (including secondary treatment, post-secondary treatment and disinfection) of the Phases 3 and 4 primary effluent and the treated effluent from Existing Works, with the Final Effluent discharged to the Silver Creek Drain, consisting of the following:

Influent Pumping Station

- one (1) sewage pump station (PS1) (regulated under Ontario Building Code) containing duplex grinder pumps rated for 1.8 litres per second at a total dynamic head of 12.3 metres discharging by 50 mm diameter forcemain to a flow equalization tank (EQ/PS2);

Preliminary Treatment System

- one (1) oil and grease interceptor (OG1), having a minimum volume capacity of 28,400 litre, receiving sewage from Phase 3 and Phase 4 kitchens, discharging to a flow equalization tank (EQ/PS2);

Primary Treatment System

- one (1) flow equalization tank EQ/PS2, receiving the effluent from the oil and grease interceptor (OG1), other raw sanitary sewage from the PS1, and the treated effluents from Phases 1 and 2 sewage treatment systems, having a total volume capacity of 60,000 litres including an active storage volume of 41,300 litres and a contingency storage volume of 18,700 litres, equipped with duplex grinder pumps rated at a discharge rate of 1.80 litres per second over a Total Dynamic Head (TDH) of 4.2 metres, discharging into a primary sedimentation tank SS1;
- two (2) primary sedimentation tanks (SS1 and SS2/PC) - SS1 comprised of one chamber for primary settling and co-thickened sludge storage, and SS2/PC comprised of two chambers for primary settling, co-thickened sludge storage and primary clarification, having a total volume capacity of 120,000 litres, accepting nitrified effluent recirculated from the Moving Bed Biofilm Reactor (MBBR) treatment unit and waste activated sludge from the MBBR process, as well as flows from the equalization tanks EQ/PS2, with sludge discharged periodically using vacuum truck;
- discharge pipe from the second chamber of primary sedimentation tank SS2/PC, discharging into a MBBR influent pump station (PS3);
- one (1) MBBR influent pump station (PS3), having a volume capacity of 15,000 cubic metres, equipped with duplex pumps each rated at a discharge rate of 2.04 litres per second over an TDH of 5.0 metres, receiving effluent from the primary sedimentation tank SS2/PC, discharging into MBBR cells;
- one (1) alkalinity dosing unit, injecting chemical into the primary sedimentation tank SS1, or the influent of MBBR influent pump station;
- two (2) chemical dosing units injecting coagulant into the primary sedimentation tank SS1 and provisionally into the MBBR effluent;

Secondary Treatment System

- two (2) Moving Bed Biofilm Reactor (MBBR) cells, operating in series, having a total volume capacity of 59,400 litres, containing a combined volume of 21 cubic metres of engineered plastic carrier media that provides 10,500 square metres of media surface area, equipped with fine bubble diffuser aeration

systems, air blowers, and effluent recirculation pump (for flow re-circulating to the primary sedimentation tank SS1, discharging effluent into a final clarifier;

- one (1) final clarifier (FC), having a total surface area of 12.8 square metres with hopper bottom and overall dimensions of 4.27 metres x 3.0 metres x 2.7 metres (H), equipped with sludge return pump and surface skimmer pump, discharging sludge into a sludge storage tank SS1, and discharging effluent via gravity into a filter feed well;
- one (1) filter feed well equipped with duplex effluent pumps to convey secondary effluent from the final clarifier (FC) to a 100 micron bag filter (provisional), discharging to two Sand Filters arranged in series;
- one (1) chemical dosing unit (provisional) injecting polymer or coagulant into the final clarifier (FC) effluent;
- two (2) NextSand Filters arranged in series, operating at a filter feed rate of 1.0 litres per second for supplementary solids polishing and particulate phosphorus removal, discharging filtered effluent via a 50 millimetre diameter discharge pipe into an ultraviolet (UV) disinfection system described below, with filter reject from the filters discharged by forcemain to primary sedimentation tank (SS1);

Disinfection

- one (1) ultraviolet disinfection system, with a Peak Hourly Flow Rate of approximately 6.81 cubic metres per hour, equipped with two (2) UV lamp modules each having two (2) lamps, discharging to the Final Effluent disposal facilities described below;

Final Effluent Disposal Facilities

- 50 mm diameter forcemain to discharge the Final Effluent from the UV disinfection unit to the Silver Creek Drain;

Final Effluent Flow Measurement and Sampling Point

- one (1) flow meter on the 50 millimetre diameter pipe from the filter feed well to the bag filter (provisional) and NextSand Filters for the measurement of Final Effluent;
- sampling point of Final Effluent: downstream of the UV disinfection unit; and

Miscellaneous

- all other mechanical systems, electrical systems, instrumentation and control systems, standby power system, piping, pumps, valves and appurtenances essential for the proper, safe and reliable operation of the Proposed Works in accordance with this Approval, in the context of process performance and general principles of wastewater engineering only.

EXISTING WORKS - Phases 1 and 2 Sewage Treatment Systems

existing two (2) (Phase 1 and Phase 2) sanitary sewage treatment systems each having Maximum Daily Flow of 9,800 litres per day and 9,875 litres per day respectively, consisting of the following:

Phase 1 Sewage Treatment System

- one (1) oil grease interceptor having a working capacity of 8,400 litres, receiving sewage from the bunkhouse kitchen and discharging into a pump tank;
- one (1) pump tank having a working capacity of 1,800 litres, receiving sewage from the above oil grease interceptor and bunkhouse/greenhouse/office washrooms, discharging into a septic tank;
- two (2) septic tanks operating in series, the first with a capacity of 29,500 litres and the second with a capacity of 9,000 litres, receiving sewage from the above pump tank, equipped with an effluent filter at the second septic tank, discharging into a balancing tank;
- one (1) flow balancing tank with a capacity of 9,100 litres, equipped with two pumps , discharging into a Waterloo Biofilter treatment unit;
- one (1) 18,200 litre precast concrete tank equipped with Waterloo Biofilter mesh baskets filled with filter media, discharging effluent via a 50 mm diameter forcemain into the forcemain connection to equalization tank EQ/PS2; and
- all other controls, electrical equipment, instrumentation, piping, valves and appurtenances essential for the proper operation of the aforementioned works.

Phase 2 Sewage Treatment System

- one (1) oil grease interceptor having a working capacity of 6,590 litres, receiving sewage from the west bunkhouse kitchen and discharging into a grinder pump tank;
- one (1) grinder pump tank having a working capacity of 3,600 litres, receiving sewage from the above oil grease interceptor and bunkhouse/greenhouse/office washrooms, discharging into a septic tank;
- one (1) oil grease interceptor having a working capacity of 6,590 litres, receiving sewage from the east bunkhouse kitchen and discharging into a septic tank;
- one (1) septic tank with a capacity of 31,800 litres, receiving sewage from the above grinder pump tank, oil grease interceptor tanks, bunkhouse/greenhouse/office washrooms, equipped with an effluent filter, discharging into a balancing tank;
- one (1) flow balancing tank with a capacity of 9,100 litres, equipped with two pumps , discharging into a Waterloo Biofilter treatment unit;

- one (1) 18,200 litre precast concrete tank equipped with Waterloo Biofilter mesh baskets filled with filter media, discharging effluent via a 50 mm diameter forcemain into the forcemain connection to equalization tank EQ/PS2; and
- all other controls, electrical equipment, instrumentation, piping, valves and appurtenances essential for the proper operation of the aforementioned works.

All in accordance with the submitted supporting documents listed in Schedule A.

For the purpose of this environmental compliance approval, the following definitions apply:

1. "Approval" means this entire Environmental Compliance Approval and any Schedules attached to it;
2. "BOD5" (also known as TBOD5) means five day biochemical oxygen demand measured in an unfiltered sample and includes carbonaceous and nitrogenous oxygen demands;
3. "CBOD5" means five day carbonaceous (nitrification inhibited) biochemical oxygen demand measured in an unfiltered sample;
4. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
5. "District Manager" means the District Manager of the appropriate local district office of the Ministry where the Works is geographically located;
6. "*E. coli* " refers to coliform bacteria that possess the enzyme beta-glucuronidase and are capable of cleaving a fluorogenic or chromogenic substrate with the corresponding release of a fluorogen or chromogen, that produces fluorescence under long wavelength (366 nm) UV light, or color development, respectively. Enumeration methods include tube, membrane filter, or multi-well procedures. Depending on the method selected, incubation temperatures include 35.5 + 0.5 °C or 44.5 + 0.2 °C (to enumerate thermotolerant species). Depending on the procedure used, data are reported as either colony forming units (CFU) per 100 mL (for membrane filtration methods) or as most probable number (MPN) per 100 mL (for tube or multi-well methods);
7. "EPA" means the *Environmental Protection Act*, R.S.O. 1990, c. E.19;
8. "Existing Works" means those portions of the Works included in the Approval that have been constructed previously;
9. "Final Effluent" means effluent that is discharged to the environment through the approved effluent disposal facilities, that are required to meet the compliance limits stipulated in the Approval for the Sewage Treatment Plant at the Final Effluent sampling point(s);
10. "Grab Sample" means an individual sample of at least 1000 millilitres collected in an appropriate

container at a randomly selected time over a period of time not exceeding 15 minutes;

11. "Influent" means flows to the Sewage Treatment Plant from the collection system;
12. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act*, R.S.O. 1990, c. P.28, as amended;
13. "Maximum Daily Flow" (also referred to as Peak Daily Flow Rate or Maximum Day Flow) means the largest volume of flow to be received during a one-day period for which the sewage treatment process unit or equipment is designed to handle;
14. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
15. "Monthly Average Effluent Concentration" is the mean of all Single Sample Results of the concentration of a contaminant in the Final Effluent sampled or measured during a calendar month;
16. "Monthly Geometric Mean Density" is the mean of all Single Sample Results of *E.coli* measurement in the samples taken during a calendar month, calculated and reported as per the methodology specified in **Schedule D**;
17. "Normal Operating Condition" means the condition when all unit process(es), excluding Preliminary Treatment System, in a treatment train is operating within its design capacity;
18. "Operating Agency" means the Owner, or the person or entity that is authorized by the Owner for the management, operation, maintenance, or alteration of the Works in accordance with this Approval;
19. "Owner" means any person that is responsible for the establishment of the Works being approved by this Approval, and includes Owner's Legal Name and its successors and assignees;
20. "OWRA" means the *Ontario Water Resources Act*, R.S.O. 1990, c. O.40;
21. "Preliminary Treatment System" means all facilities in the Sewage Treatment Plant associated with screening and grit removal;
22. "Primary Treatment System" means all facilities in the Sewage Treatment Plant associated with the primary sedimentation unit process and includes chemically enhanced primary treatment;
23. "Proposed Works" means those portions of the Works included in the Approval that are under construction or to be constructed;
24. "Secondary Treatment System" means all facilities in the Sewage Treatment Plant associated

with biological treatment, secondary sedimentation and phosphorus removal unit processes;

25. "Sewage Treatment Plant" means all the facilities related to sewage treatment within the sewage treatment plant site excluding the Final Effluent disposal facilities;
26. "Single Sample Result" means the test result of a parameter in the effluent discharged on any day, as measured by a probe, analyzer or in a composite or grab sample, as required;
27. "Works" means the approved sewage works includes Proposed Works and Existing Works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

TERMS AND CONDITIONS

1. GENERAL PROVISIONS

1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
3. Where there is a conflict between a provision of any document referred to in this Approval and the conditions of this Approval, the conditions in this Approval shall take precedence.

2. CHANGE OF OWNER AND OPERATING AGENCY

1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
 - a. change of address of Owner;
 - b. change of Owner, including address of new owner;
 - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act*, R.S.O. 1990, c. B.17 shall be included in the notification;
 - d. change of name of the corporation and a copy of the most current information filed under the *Corporations Information Act*, R.S.O. 1990, c. C.39 shall be included in the notification.
2. The Owner shall notify the District Manager, in writing, of any of the following changes within **thirty**

(30) days of the change occurring:

- a. change of address of the Operating Agency;
 - b. change of the Operating Agency, including address of the new Operating Agency.
3. In the event of any change in ownership of the Works, the Owner shall notify the succeeding owner in writing, of the existence of this Approval, and forward a copy of the notice to the District Manager.
 4. The Owner shall ensure that all communications made pursuant to this condition refer to the number of this Approval.

3. CONSTRUCTION OF PROPOSED WORKS

1. All Proposed Works in this Approval shall be constructed and installed and must commence operation within **five (5) years** of issuance of this Approval, after which time the Approval ceases to apply in respect of any portions of the Works not in operation. In the event that the construction, installation and/or operation of any portion of the Proposed Works is anticipated to be delayed beyond the time period stipulated, the Owner shall submit to the Director an application to amend the Approval to extend this time period, at least six (6) months prior to the end of the period. The amendment application shall include the reason(s) for the delay and whether there is any design change(s).
2. Upon completion of construction of the Proposed Works, the Owner shall prepare and submit a written statement to the District Manager, certified by a Licensed Engineering Practitioner, that the Proposed Works is constructed in accordance with this Approval.
3. **One (1) week** prior to the commencement of the operation of the Proposed Works, the Owner shall notify the District Manager (in writing) of the pending start-up date.
4. Within **one (1) year** of completion of construction of the Proposed Works, a set of record drawings of the Works shall be prepared or updated. These drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be readily accessible for reference at the Works.

4. DESIGN OBJECTIVES

1. The Owner shall design and undertake everything practicable to operate the Works in accordance with the following objectives:
 - a. Final Effluent is essentially free of floating and settleable solids and does not contain oil or any other substance in amounts sufficient to create a visible film or sheen or foam or discolouration on the surface receiving waters.
 - b. The total Maximum Daily Flow is within the design capacity of the Works - 75,000 litre per day.

5. COMPLIANCE LIMITS

1. The Owner shall operate and maintain the Sewage Treatment Plant such that compliance limits for the Final Effluent parameters listed in the tables included in **Schedule B** are met.
2. The Owner shall operate and maintain the Sewage Treatment Plant such that the Final Effluent is disinfected continuously year-round, or during operation for seasonal operation.
3. The Owner shall cease discharge of any non-compliant effluent to the Silver Creek Drain from the Works within 24 hours under the following conditions, until the treatment system returns to compliance.
 - a. Upon request by the District Manager.
 - b. Should the concentration of Total Ammonia Nitrogen (TAN) in the Final Effluent exceed 4.0 milligrams per litre during the summer (May 01 to October 31) or 6.0 milligrams per litre during the winter (November 01 to April 30) during the operational life of the Sewage Treatment Plant, including start-up and commissioning, the Owner shall notify the District Manager pursuant to subsection 2 of Condition 8 (regarding reporting) and stop discharging to the receiver within twenty-four (24) hours.
4. Under the cease-discharging conditions pursuant to above subsections 3.a. or 3.b., the Owner shall implement the contingency measures pursuant to subsection 2.f. of Condition 6 (regarding operation and maintenance), and ensure the non-compliant effluent be either recirculated through the treatment system for re-treatment for compliance, or be hauled off-site to an approved waste disposal site by a registered waste hauler.
5. Upon the Sewage Treatment Plant returning to compliance, the Owner shall ensure the District Manager be notified prior to discharge resumption.

6. OPERATION AND MAINTENANCE

1. The Owner shall ensure that, at all times, the Works and the related equipment and appurtenances used to achieve compliance with this Approval are properly operated and maintained. Proper operation and maintenance shall include effective performance, adequate staffing and training, including training in all procedures and other requirements of this Approval and the OWRA and relevant regulations made under the OWRA, process controls and alarms and the use of process chemicals and other substances used in the Works.
2. The Owner shall prepare/update the operations manual for the Works within six (6) months of completion of construction of the Proposed Works, that includes, but not necessarily limited to, the following information:
 - a. operating procedures for the Works under Normal Operating Conditions;
 - b. inspection programs, including frequency of inspection, for the Works and the methods or tests

- employed to detect when maintenance is necessary;
- c. repair and maintenance programs, including the frequency of repair and maintenance for the Works;
 - d. procedures for the inspection and calibration of monitoring equipment;
 - e. operating procedures for the Works to handle situations outside Normal Operating Conditions and emergency situations such as a structural, mechanical or electrical failure, or an unforeseen flow condition;
 - f. a spill prevention control and countermeasures plan, consisting of contingency plans and procedures for dealing with equipment breakdowns, potential spills and any other abnormal situations, including notification of the Spills Action Centre (SAC) and District Manager;
 - g. procedures for receiving, responding and recording public complaints, including recording any follow-up actions taken.
3. The Owner shall maintain an up to date operations manual and make the manual readily accessible for reference at the Works for the operational life of the Works. Upon request, the Owner shall make the manual available to Ministry staff.
 4. The Owner shall ensure that the Operating Authority possesses the level of training and experience sufficient to allow safe and environmentally sound operation of the Works.
 5. The Owner shall ensure the oil and grease interceptors be cleaned out at least once per year, or more frequently as determined by the Operating Authority, for removal of fats, oil and grease from the kitchen wastewater prior to discharging the sewage to the flow equalization tanks or septic tanks.
 6. The Owner shall have a valid written agreement with a hauler who is in possession of a Waste Management Systems Approval, for the treatment and disposal of the sludge generated from the Works, at all times during operation of the Works.
 7. The Owner shall ensure that the septic tank is pumped out every 3-5 years or when the tank is 1/3 full of solids and the effluent filter is cleaned out at minimum once a year (or more often if required).
 8. The Owner shall maintain a logbook to record the results of all inspections, repair and maintenance undertaken, calibrations, monitoring and spill response or contingency measures undertaken and shall make the logbook available for inspection by Ministry staff. The logbook shall include the following:
 - a. the name of the operator making the entry; and
 - b. the date and results of each inspection, repair, maintenance, calibration, monitoring, spill response and contingency measure.

7. MONITORING AND RECORDING

1. The Owner shall, upon commencement of operation of the Works, carry out a scheduled monitoring program of collecting samples at the required sampling points, at the frequency specified or higher, by means of the specified sample type and analyzed for each parameter listed in the tables under the monitoring program included in **Schedule C** and record all results, as follows:
 - a. all samples and measurements are to be taken at a time and in a location characteristic of the quality and quantity of the sewage stream over the time period being monitored.
 - b. definitions and preparation requirements for each sample type are included in document referenced in Paragraph 2.b.
 - c. definitions for frequency:
 - i. Weekly means once every week
 - ii. Monthly means once every month
 - iii. Annually means once every year
 - d. a schedule of the day of the week/month for the scheduled sampling shall be created. The sampling schedule shall be revised and updated every year through rotation of the day of the week/month for the scheduled sampling program, except when the actual scheduled monitoring frequency is three (3) or more times per week.
 - e. The measurement frequencies specified in **Schedule C** in respect to any parameter may, after **two (2) years** of monitoring in accordance with this Condition, be modified by the Director in writing.
2. The methods and protocols for sampling, analysis and recording shall conform, in order of precedence, to the methods and protocols specified in the following documents and all analysis shall be conducted by a laboratory accredited to the ISO/IEC:17025 standard or as directed by the District Manager:
 - a. the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works (Liquid Waste Streams Only), as amended;
 - b. the Ministry's publication "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater Version 2.0" (January 2016), PIBS 2724e02, as amended;
 - c. the publication "Standard Methods for the Examination of Water and Wastewater", as amended; and
 - d. for any parameters not mentioned in the documents referenced in Paragraphs 3.a, 3.b and 3.c, the written approval of the District Manager shall be obtained prior to sampling.
3. The Owner shall monitor and record the flow rate and daily quantity using flow measuring devices or other methods of measurement as approved below calibrated to an accuracy within plus or minus 15 per

cent (+/- 15%) of the actual flowrate of the following:

- a. Influent flow to the Sewage Treatment Plant by instrumentations/pumping rates; and
 - b. Final Effluent discharged from the Sewage Treatment Plant by continuous flow measuring devices.
4. The Owner shall retain for a minimum of five (5) years from the date of their creation, all records and information related to or resulting from the monitoring activities required by this Approval.

8. REPORTING

1. One week prior to the start up of the operation of the Proposed Works, the Owner shall notify the District Manager (in writing) of the pending start up date.
2. The Owner shall report to the District Manager orally as soon as possible any non-compliance with the effluent compliance limits, and in writing within seven (7) days of non-compliance.
3. In addition to the obligations under Part X of the EPA and O. Reg. 675/98 (Classification and Exemption of Spills and Reporting of Discharges) made under the EPA, the Owner shall, within fifteen (15) days of the occurrence of any reportable spill as provided in Part X of the EPA and O. Reg. 675/98, submit a full written report of the occurrence to the District Manager describing the cause and discovery of the spill, clean-up and recovery measures taken, preventative measures to be taken and a schedule of implementation.
4. The Owner shall, upon request, make all manuals, plans, records, data, procedures and supporting documentation available to Ministry staff.
5. The Owner shall prepare performance reports on a calendar year basis and submit to the District Manager in an electronic format by **June 30** of the calendar year following the period being reported upon. The reports shall contain, but shall not be limited to, the following information pertaining to the reporting period:
 - a. a summary and interpretation of all Influent monitoring data, and a review of the historical trend of the sewage characteristics and flow rates;
 - b. a summary and interpretation of all Final Effluent monitoring data, including concentration, flow rates, and a comparison to the design objectives and compliance limits in this Approval, including an overview of the success and adequacy of the Works;
 - c. a summary of all operating issues encountered and corrective actions taken;
 - d. a summary of all normal and emergency repairs and maintenance activities carried out on any major structure, equipment, apparatus or mechanism forming part of the Works;

- e. a summary of any effluent quality assurance or control measures undertaken;
- f. a summary of the calibration and maintenance carried out on all Influent, and Final Effluent monitoring equipment to ensure that the accuracy is within the tolerance of that equipment as required in this Approval or recommended by the manufacturer;
- g. a description of efforts made and results achieved in meeting the design objectives outlined in Condition 4;
- h. a tabulation of the volume of sludge generated, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;
- i. a summary of any complaints received and any steps taken to address the complaints;
- j. a summary of all other situations outside Normal Operating Conditions and spills within the meaning of Part X of EPA and abnormal discharge events;
- k. any changes or updates to the schedule for the completion of construction and commissioning operation of major process(es) / equipment groups in the Proposed Works; and
- l. any other information the District Manager requires from time to time.

9. DECOMMISSIONING OF UN-USED SYSTEM

- 1. The Owner shall, within one (1) year after the issuance of the Approval, properly abandon any portion of unused two (2) shallow buried trench effluent disposal beds, as directed below, and upon completion of decommissioning report in writing to the District Manager:
 - a. the existing disposal beds may be abandoned in place after disconnecting, if there are no other plans to use the area for other purposes.

Schedule A

1. Application for Environmental Compliance Approval dated March 9, 2023 and received on March 10, 2023, and submitted by Peter Giesbrecht, President of JPI Farms Inc., for the Phases 1 to 4 sanitary sewage treatment systems and Final Effluent disposal facility, including design brief, engineering drawings and specifications.

Schedule B

Final Effluent Compliance Limits For the Final Effluent from the Sewage Treatment Plant

| Effluent Parameter | Monthly Average Effluent Concentration* ¹ Limits (maximum unless otherwise indicated) | |
|--|---|---------------------------------------|
| | Summer (May 01 to October 31) | Winter (November 01 to April 30) |
| <i>Column 1</i> | <i>Column 2</i> | <i>Column 3</i> |
| CBOD5 | 10.0 mg/L* ² | 15.0 mg/L |
| Total Suspended Solids (TSS) | 10.0 mg/L | 15.0 mg/L |
| Total Phosphorus (TP) | 0.3 mg/L | 0.3 mg/L |
| Total Ammonia Nitrogen (TAN)* ³ | 2.0 mg/L | 3.0 mg/L |
| <i>E. coli.</i> | 100 CFU/100 millilitres* ⁴ | 100 CFU/100 millilitres* ⁴ |

Note*¹: The limit of *E.coli.* is for monthly Geometric Mean Density.

Note*²: mg/L means milligrams per litre.

Note*³: During commissioning stage, **six (6) months** after the date of start-up, an interim compliance limit applies for the Total Ammonia Nitrogen (TAN) as: 4.0 mg/L during Summer (May 01 to October 31), or 6.0 mg/L during Winter (November 01 to April 30).

Note*⁴: If the MPN method is utilized for *E. coli* analysis, the limit shall be 100 MPN/100 millilitres.

Schedule C - Monitoring Program

Table C-1 Influent Monitoring

| | |
|-------------------------|---|
| Sample locations | one (1) sampling point at the flow equalization tank EQ/PS2 |
| Frequency | Monthly |
| Sample Type | Grab |
| Parameters | BOD5, Total Suspended Solids, Total Phosphorus, Total Ammonia Nitrogen, Total Kjeldahl Nitrogen, pH |

Table C-2 Final Effluent Monitoring

| | |
|------------------------|--|
| Sample location | Final Effluent from the UV disinfection unit, prior to discharging into the Silver Creek Drain |
| Frequency | Weekly |
| Sample Type | Minimum 8-hour Composite (except <i>E. Coli.</i> , pH, and Temperature) |
| Parameters | CBOD5, Total Suspended Solids, Total Ammonia Nitrogen, Total Phosphorus, <i>E. coli.</i> (grab), pH*(grab/probe/analyzer), and Temperature*(grab/probe/analyzer) |

Note*: pH and temperature of the Final Effluent shall be determined in the field at the time of sampling for Total Ammonia Nitrogen.

Table C-3 Sludge/Biosolids Sampling

Sampling location: Sludge Storage Tank and Septic/Sludge Tank, as one combined sample

| Parameters | Sample Type | Minimum Frequency |
|--|--------------------|--------------------------|
| Total Solids | Grab | Annually |
| Total Phosphorus | Grab | Annually |
| Total Ammonia Nitrogen | Grab | Annually |
| Nitrate as Nitrogen | Grab | Annually |
| Metal Scan - Arsenic - Cadmium - Cobalt - Chromium - Copper - Lead - Mercury - Molybdenum - Nickel - Potassium - Selenium - Zinc | Grab | Annually |

Schedule D

Methodology for Calculating and Reporting Monthly Geometric Mean Density

Geometric mean is defined as the n^{th} root of the product of n numbers. In the context of calculating Monthly Geometric Mean Density for *E. coli*, the following formula shall be used:

$$\sqrt[n]{x_1 x_2 x_3 \cdots x_n}$$

in which,

" n " is the number of samples collected during the calendar month; and

" x " is the value of each Single Sample Result.

For example, four weekly grab samples were collected and tested for *E. coli* during the calendar month. The *E. coli* densities in the Final Effluent were found below:

| Sample Number | <i>E. coli</i> Densities* (CFU/100 mL) |
|---------------|--|
| 1 | 10 |
| 2 | 100 |
| 3 | 300 |
| 4 | 50 |

The Geometric Mean Density for these data:

$$\sqrt[4]{10 \times 100 \times 300 \times 50} = 62$$

*If a particular result is zero (0), then a value of one (1) will be substituted into the calculation of the Monthly Geometric Mean Density. If the MPN method is utilized for *E. coli* analysis, values in the table shall be MPN/100 mL.

The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 regarding general provisions is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted.
2. Condition 2 regarding change of Owner and Operating Agency is included to ensure that the Ministry records are kept accurate and current with respect to ownership and Operating Agency of the Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
3. Condition 3 regarding construction of Proposed Works is included to ensure that the Works are constructed in a timely manner so that standards applicable at the time of Approval of the Works are still applicable at the time of construction to ensure the ongoing protection of the environment, and that prior to the commencement of construction of the portion of the Works that are approved in principle only, the Director will have the opportunity to review detailed design drawings, specifications and an engineer's report containing detailed design calculations for that portion of the Works, to determine capability to comply with the Ministry's requirements stipulated in the terms and conditions of the Approval, and also ensure that the Works are constructed in accordance with the Approval and that record drawings of the Works "as constructed" are updated and maintained for future references.
4. Condition 4 regarding design objectives is imposed to establish non-enforceable design objectives to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs.
5. Condition 5 regarding compliance limits is imposed to ensure that the Final Effluent discharged from the Works to the environment meets the Ministry's effluent quality requirements.
6. Condition 6 regarding operation and maintenance is included to require that the Works be properly operated, maintained, funded, staffed and equipped such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented. As well, the inclusion of a comprehensive operations manual governing all significant areas of operation, maintenance and repair is prepared, implemented and kept up-to-date by the Owner. Such a manual is an integral part of the operation of the Works. Its compilation and use should assist the Owner in staff training, in proper plant operation and in identifying and planning for contingencies during possible abnormal conditions. The manual will also act as a benchmark for Ministry staff when reviewing the Owner's operation of the Works.
7. Condition 7 regarding monitoring and recording is included to enable the Owner to evaluate and demonstrate the performance of the Works, on a continual basis, so that the Works are properly operated and maintained at a level which is consistent with the design objectives and compliance limits.

8. Condition 8 regarding reporting is included to provide a performance record for future references, to ensure that the Ministry is made aware of problems as they arise, and to provide a compliance record for this Approval.
9. Condition 9 is included to ensure that any components of un-used existing two (2) shallow buried trench effluent disposal beds are properly decommissioned.

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights, 1993*, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Hearing") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The environmental compliance approval number;
4. The date of the environmental compliance approval;
5. The name of the Director, and;
6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar*
Ontario Land Tribunal
655 Bay Street, Suite 1500
Toronto, Ontario
M5G 1E5
OLT.Registrar@ontario.ca

and

The Minister of the Environment,
Conservation and Parks
777 Bay Street, 5th Floor
Toronto, Ontario
M7A 2J3

and


The Director appointed for the purposes of
Part II.1 of the *Environmental Protection Act*
Ministry of the Environment,
Conservation and Parks
135 St. Clair Avenue West, 1st Floor
Toronto, Ontario
M4V 1P5

*** Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca**

This instrument is subject to Section 38 of the *Environmental Bill of Rights, 1993*, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at <https://ero.ontario.ca/>, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the *Environmental Protection Act*.

DATED AT TORONTO this 7th day of December, 2023

A handwritten signature in black ink that reads "Fariha Pannu." The signature is written in a cursive style with a large, sweeping initial 'F'.

Fariha Pannu, P.Eng.

Director

appointed for the purposes of Part II.1 of the
Environmental Protection Act

NH/

c: Area Manager, MECP Windsor Area Office

c: District Manager, MECP Sarnia District Office

Richard J. Pellerin, P.Eng., Sco-Terra Consulting Group Limited