

Ministry of the Environment, Conservation and Parks Ministère de l'Environnement, de la Protection de la nature et des Parcs

#### ENVIRONMENTAL COMPLIANCE APPROVAL

NUMBER 5706-CVZNWN Issue Date: April 9, 2024

Umicore Battery Materials Canada Inc. 215 Main St, Unit 1, Bath, Ontario K0H 1G0

Site Location: 195 County Road 4 Bath, Loyalist Township County of Lennox and Addington, Ontario K0H 1G0

You have applied under section 20.2 of Part II.1 of the <u>Environmental Protection Act</u>, R.S.O. 1990, c. E. 19 (Environmental Protection Act) for approval of:

the establishment, usage and operation of stormwater conveyance Works servicing a precursor cathode active material (pCAM) and cathode active material (CAM) production facility at the above site location, consisting of the following:

- proposed storm sewers of 250 to 2,000 millimetre diameters, located across the proposed Wave 1 and Wave 2 development areas (total catchment area of approximately 58 hectares), receiving stormwater runoff from the said areas and discharging to two (2) proposed stormwater management facilities (Ponds No. 1 & 2, to be approved separately) that outlet to Millhaven Creek and Lake Ontario;
- one (1) proposed trapezoidal Northern Diversion Ditch, located along the north and northwest property boundaries, having a total length of approximately 619 metres, a base width of 1.5 metres, a depth of minmum 1.0 metre, side slopes of 1:3 and a longitudinal slope of minimum 0.2%, receiving stormwater flows from approximately 22.8 hectares of external catchment areas to the north and west of the developed area and discharging southerly to the County Road 4 roadside ditch;
- one (1) proposed trapezoidal North-South Ditch, located to the south of the production facilities, having a total length of approximately 383 metres, a base width of 1.0 metre, a depth of minmum 1.0 metre, side slopes of 1:3 and varying longitudinal slopes, receiving stormwater flows from approximately 1.8 hectares of developed area and discharging to the proposed Pond No. 2 (to be approved separately) via two (2) proposed storm sewers in sequence, with a diameter of 900 millimetres and 1,050 millimetres, respectively;

including erosion/sedimentation control measures during construction and all other controls and appurtenances essential for the proper operation of the aforementioned Works;

all in accordance with the submitted application and supporting documents listed in **Schedule A** forming part of this Approval.

For the purpose of this environmental compliance approval, the following definitions apply:

- 1. "Approval" means this entire Environmental Compliance Approval and any Schedules attached to it;
- 2. "Director" means a person appointed by the Minister pursuant to section 5 of the EPA for the purposes of Part II.1 of the EPA;
- 3. "District Manager" means the District Manager of the appropriate local district office of the Ministry, where the Works are geographically located;
- 4. "EPA" means the Environmental Protection Act, R.S.O. 1990, c.E.19, as amended;
- 5. "Licensed Engineering Practitioner" means a person who holds a licence, limited licence or temporary licence under the *Professional Engineers Act,* R.S.O. 1990, c. P.28;
- 6. "Ministry" means the ministry of the government of Ontario responsible for the EPA and OWRA and includes all officials, employees or other persons acting on its behalf;
- 7. "Owner" means Umicore Rechargeable Battery Materials Canada Inc., and includes its successors and assignees;
- 8. "OWRA" means the Ontario Water Resources Act, R.S.O. 1990, c. O.40, as amended;
- 9. "Works" means the aproved sewage works.

You are hereby notified that this environmental compliance approval is issued to you subject to the terms and conditions outlined below:

#### **TERMS AND CONDITIONS**

#### 1. GENERAL CONDITIONS

- 1. The Owner shall ensure that any person authorized to carry out work on or operate any aspect of the Works is notified of this Approval and the terms and conditions herein and shall take all reasonable measures to ensure any such person complies with the same.
- 2. The Owner shall design, construct, operate and maintain the Works in accordance with the conditions of this Approval.
- 3. Where there is a conflict between a provision of any document referred to in this Approval and the

conditions of this Approval, the conditions in this Approval shall take precedence.

- 4. The issuance of, and compliance with the conditions of, this Approval does not:
  - a. relieve any person of any obligation to comply with any provision of any applicable statute, regulation or other legal requirement, including, but not limited to, the obligation to obtain approval from the local conservation authority necessary to construct or operate the Works; or
  - b. limit in any way the authority of the Ministry to require certain steps be taken to require the Owner to furnish any further information related to compliance with this Approval.

#### 2. EXPIRY OF APPROVAL

- 1. This Approval will cease to apply to those parts of the Works which have not been constructed within **five (5) years** of the date of this Approval.
- 2. In the event that completion and commissioning of any portion of the Works is anticipated to be more than five (5) years, the Owner shall submit an application for extension at least twelve (12) months prior to the end of the five (5) years from the day of issuance of this Approval. The application shall include the reason(s) for the delay, whether there is any design change(s) and a review of whether the standards applicable at the time of Approval of the Works are still applicable at the time of request for extension, to ensure the ongoing protection of the environment.

#### 3. CHANGE OF OWNER

- 1. The Owner shall notify the District Manager and the Director, in writing, of any of the following changes within **thirty (30) days** of the change occurring:
  - a. change of address of Owner;
  - b. change of Owner, including address of new owner;
  - c. change of partners where the Owner is or at any time becomes a partnership, and a copy of the most recent declaration filed under the *Business Names Act, R.S.O. 1990, c. B.17* shall be included in the notification; or
  - d. change of name of the corporation, and a copy of the most current information filed under the *Corporations Information Act, R.S.O. 1990, c. C39* shall be included in the notification.
- 2. In the event of any change in ownership of the Works, the Owner shall notify in writing the succeeding owner of the existence of this Approval, and a copy of such notice shall be forwarded to the District Manager and the Director.
- 3. The Owner shall ensure that all communications made pursuant to this condition refer to the number

of this Approval.

### 4. CONSTRUCTION

- 1. Upon the construction of the Works, the Owner shall prepare a statement, certified by a Licensed Engineering Practitioner, that the Works are constructed in accordance with this Approval, and upon request, shall make the written statement available for inspection by Ministry personnel.
- 2. Within **one (1) year** of the construction of the Works, a set of as-built drawings showing the Works "as constructed" shall be prepared. These drawings shall be kept up to date through revisions undertaken from time to time and a copy shall be retained at the Works for the operational life of the Works.

#### 5. TEMPORARY EROSION AND SEDIMENT CONTROL

- 1. The Owner shall install and maintain temporary sediment and erosion control measures during construction and conduct inspections **once every two (2) weeks** and after each significant storm event (a significant storm event is defined as a minimum of 25 millimetres of rain in any 24 hours period). The inspections and maintenance of the temporary sediment and erosion control measures shall continue until they are no longer required and at which time they shall be removed and all disturbed areas reinstated properly.
- 2. The Owner shall maintain records of inspections and maintenance which shall be made available for inspection by the Ministry, upon request. The record shall include the name of the inspector, date of inspection, and the remedial measures, if any, undertaken to maintain the temporary sediment and erosion control measures.

## 6. OPERATION AND MAINTENANCE

1. Upon issuance of this Approval, the Works may be constructed but they shall not be operated until such a time as the proposed stormwater management facilities Ponds No. 1 & 2, referenced in this Approval, that are intended to service the Works or any other stormwater conveyance infrastructure located on the site location, have received an environmental compliance approval and are in operation.

#### The reasons for the imposition of these terms and conditions are as follows:

1. Condition 1 is imposed to ensure that the Works are constructed and operated in the manner in which they were described and upon which approval was granted. This condition is also included to emphasize the precedence of conditions in the Approval and the practice that the Approval is based on the most current document, if several conflicting documents are submitted for review. Condition 1.4 is included to emphasize that the issuance of this Approval does not diminish any other statutory and regulatory obligations to which the Owner is subject in the construction, maintenance and operation of the Works. The Condition specifically highlights the need to

obtain any necessary conservation authority approvals. The Condition also emphasizes the fact that this Approval doesn't limit the authority of the Ministry to require further information.

- 2. Condition 2 is included to ensure that, when the Works are constructed, the Works will meet the standards that apply at the time of construction to ensure the ongoing protection of the environment.
- 3. Condition 3 is included to ensure that the Ministry records are kept accurate and current with respect to the approved Works and to ensure that subsequent owners of the Works are made aware of the Approval and continue to operate the Works in compliance with it.
- 4. Condition 4 is included to ensure that the Works are constructed in accordance with the approval and that record drawings of the Works "as constructed" are maintained for future references.
- 5. Condition 5 is included as installation, regular inspection and maintenance of the temporary sediment and erosion control measures is required to mitigate the impact on the downstream receiving watercourse during construction until they are no longer required.
- 6. Condition 6 is included to prevent the operation of stormwater pipes and other conveyance works until such time that their required associated stormwater management Works are also constructed.

# Schedule A

- 1. Environmental Compliance Approval Application for Industrial Sewage Works submitted by Ramboll Canada Inc. on behalf of Umicore Rechargeable Battery Materials Canada Inc., dated July 11, 2023 and received on July 10, 2023, and all supporting documentation and information.
- Umicore Rechargeable Battery Materials Canada Inc. Stormwater Management Report, PACMAN Project -Precursor & Cathode Active Materials (Rev C05: LYL2-GEN-000-REP-09-002), including all associated drawings and specifications, dated March 25, 2024 and prepared by Worley Canada Services Ltd.
- 3. Memorandum re. Changes to Stormwater Management Report, dated March 25, 2024 and prepared by Worley Canada Services Ltd.
- 4. Memorandum re. Clarification for Stormwater Management Report Revision C05, dated March 28, 2024 and prepared by Worley Canada Services Ltd.
- 5. Memorandum re. Clarification for Stormwater Management Report Revision C05, dated April 3, 2024 and prepared by Worley Canada Services Ltd.

In accordance with Section 139 of the *Environmental Protection Act*, you may by written notice served upon me, the Ontario Land Tribunal and in accordance with Section 47 of the *Environmental Bill of Rights*, 1993, the Minister of the Environment, Conservation and Parks, within 15 days after receipt of this notice, require a hearing by the Tribunal. The Minister of the Environment, Conservation and Parks will place notice of your appeal on the Environmental Registry. Section 142 of the *Environmental Protection Act* provides that the notice requiring the hearing ("the Notice") shall state:

- a. The portions of the environmental compliance approval or each term or condition in the environmental compliance approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

- 1. The name of the appellant;
- 2. The address of the appellant;
- 3. The environmental compliance approval number;
- 4. The date of the environmental compliance approval;
- 5. The name of the Director, and;
- 6. The municipality or municipalities within which the project is to be engaged in.

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

Registrar* Ontario Land Tribunal 655 Bay Street, Suite 1500 Toronto, Ontario M5G 1E5 OLT.Registrar@ontario.ca	and	The Minister of the Environment, Conservation and Parks 777 Bay Street, 5th Floor Toronto, Ontario M7A 2J3	and	The Director appointed for the purposes of Part II.1 of the <i>Environmental Protection Act</i> Ministry of the Environment, Conservation and Parks 135 St. Clair Avenue West, 1st Floor Toronto, Ontario M4V 1P5
--	-----	--	-----	---

\* Further information on the Ontario Land Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349 or 1 (866) 448-2248, or www.olt.gov.on.ca

This instrument is subject to Section 38 of the *Environmental Bill of Rights*, 1993, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek leave to appeal within 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry at https://ero.ontario.ca/, you can determine when the leave to appeal period ends.

The above noted activity is approved under s.20.3 of Part II.1 of the Environmental Protection Act.

DATED AT TORONTO this 9th day of April, 2024

Fariha Parnu.

Fariha Pannu, P.Eng. Director appointed for the purposes of Part II.1 of the *Environmental Protection Act* 

SW/

c: District Manager, MECP Kingston District Office Felix Kristanovich, Ramboll Canada Inc.