

UTM 172 403340E



WATER RESOURCES DIVISION
 33 No. 329
 SEP 30 1965
 ONTARIO WATER RESOURCES COMMISSION

GORE 5R 4717900N
 The Ontario Water Resources Commission Act

Elev. 5R 7016100
WATER WELL RECORD

Basin 23 | KENT
 County or District | Township, Village, Town or City CAMDEN DRESDEN

Con. 5 | Lot 7 | Date completed 13 AUG 65
 (day month year)
 Address Dresden

Casing and Screen Record

Inside diameter of casing 4"
 Total length of casing 41'
 Type of screen BRASS
 Length of screen 3' + 2 1/2" NIP
 Depth to top of screen 41'
 Diameter of finished hole 3"

Pumping Test

Static level 14'
 Test-pumping rate 4 G.P.M.
 Pumping level 35'
 Duration of test pumping 2 hrs
 Water clear or cloudy at end of test clear
 Recommended pumping rate 3 G.P.M.
 with pump setting of 40' feet below ground surface

Well Log

Water Record

Overburden and Bedrock Record	From ft.	To ft.	Depth(s) at which water(s) found	Kind of water (fresh, salty, sulphur)
<u>Top soil</u>	<u>0</u>	<u>2</u>		
<u>yellow clay</u>	<u>2</u>	<u>8</u>	<u>46</u>	<u>fresh</u>
<u>Blue clay</u>	<u>8</u>	<u>36</u>		
<u>Sand + gravel</u>	<u>36</u>	<u>46</u>		
<u>Hard pan</u>	<u>46</u>	<u>52'</u>		

For what purpose(s) is the water to be used? 19

Is well on upland, in valley, or on hillside? flat upland

Drilling or Boring Firm as below

Address as below

Licence Number 1824

Name of Driller or Borer RW Simpson

Address Dresden Ont R.R.# 2

Date Aug 13/65

RW Simpson
 (Signature of Licensed Drilling or Boring Contractor)

Location of Well

In diagram below show distances of well from road and lot line. Indicate north by arrow.

